

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-013074**Date Inspected:** 02-Apr-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China

CWI Name:	N/A	CWI Present:	Yes	No
Inspected CWI report:	Yes No N/A	Rod Oven in Use:	Yes No N/A	
Electrode to specification:	Yes No N/A	Weld Procedures Followed:	Yes No N/A	
Qualified Welders:	Yes No N/A	Verified Joint Fit-up:	Yes No N/A	
Approved Drawings:	Yes No N/A	Approved WPS:	Yes No N/A	
		Delayed / Cancelled:	Yes No N/A	
Bridge No:	34-0006	Component:	TOWER	

Summary of Items Observed:

This CALTRANS OSM Quality Assurance Inspector (QA) Surendra Prabhu was present during the times noted above for observations relative to the fabrication of the Self Anchored Suspension (SAS) Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island, in Shanghai, China. QA observed and/or found the following:

BAY:11 (TOWER).

The following Non Destructive Testing (NDT) Inspection carried out as per the ZPMC submitted Notification No. 005458.

Magnetic Particle Testing (MT)

This QA performed MT of approximately 15% of the area previously tested and accepted by ZPMC Quality Control (QC) personnel. This QA generated MT report for this date. The member is identified as Tower-Lift4-strut weld Components. Total number of welds MT Tested: 38 No's (from side A and B). The weld designations are review as follows:

- SD1-STSA4-5-119M-1-1A/B, 3A/B.
- WD1-STSA4-5-119M-1-1A/B, 3A/B.
- SD1-STSA4-5-123M-1-1A/B, 3A/B.
- WD1-STSA4-5-123M-1-1A/B, 3A/B.
- SD1-STSA4-5-127M-1-1A/B, 3A/B.
- ED1-STSA4-6-127M-2-2A/B, 4A/B.
- ND1-STSA4-6-127M-2-2A/B, 4A/B.
- ED1-STSA4-6-131M-2-2A/B, 4A/B.

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

- | | |
|-------------------------------------|-------------------------------------|
| 9. ND1-STSA4-6-135M-2-1A/B, 3A/B. | 10. ED1-STSA4-6-139M-2-1A/B, 3A/B. |
| 11. ND1-STSA4-6-139M-2-1A/B, 3A/B. | 12. ND1-STSA4-10-119M-1-5A/B, 6A/B. |
| 13. ND1-STSA4-10-119M-2-5A/B, 6A/B. | 14. ED1-STSA4-10-119M-1-5A/B, 6A/B. |
| 15. ED1-STSA4-10-119M-2-5A/B, 6A/B. | 16. ND1-STSA4-6-127M-1-2A/B, 4A/B. |
| 17. ED1-STSA4-6-131M-1-2A/B, 4A/B. | 18. ED1-STSA4-6-139M-1-1A/B, 3A/B. |
| 19. ND1-STSA4-6-139M-1-1A/B, 3A/B. | |

TOWER TRIAL ASSEMBLY(JETTY)

The following Non Destructive Testing (NDT) Inspection carried out as per the ZPMC submitted Notification No. 005461.

This QA performed MT of approximately 15% of the area previously tested and accepted by ZPMC Quality Control (QC) personnel. This QA generated MT report for this date. The member is identified as Tower- North Tower Bearing Plate weld Components. Total number of welds MT Tested: 09 No's. The weld designations are review as follows:

1. NSD1-SA76F/H-29, 33, 34, 39, 45, 46, 51, 52&57.

The following Non Destructive Testing (NDT) Inspection carried out as per the ZPMC submitted notification No: 005461.

Visual Inspection (VT)

This QA Inspector performed VT of the area previously tested and accepted by ZPMC QC Personnel. The member is identified as Tower-North Tower Bearing Plate weld Components. The weld designations are review as follows:

1. NSD1-SA76F/H-29, 33, 34, 39, 45, 46, 51, 52&57.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.

Summary of Conversations:

Only general conversation was held between QA and Quality Control (QC) concerning this project.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Skyler Guest 15000422360, who represents the Office of Structural Materials for your project.

Inspected By:	Prabhu,Surendra	Quality Assurance Inspector
Reviewed By:	Miller,Mark	QA Reviewer
