

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-014761**Date Inspected:** 13-Jun-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** An Qing Xiang.**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Tower**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance (QA) Inspector Shailesh Gaikwad was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island in Shanghai, China. QA observed and/or found the following:

This QA Inspector observed the following work in progress:

BAY 11:

SMAW Process,

This QA Inspector observed ZPMC qualified welding personnel identified as 040724, 251194, Perform Shielded Metal Arc Welding (SMAW) on Tower strut. Joint identified as SD1-STSA4-5-143M-1-13, 14, 15, 16, ZPMC CWI Identified as Yu Dong Ping, The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-2113.

This QA Inspector observed ZPMC qualified welding personnel identified as 040619, 046704, Perform Shielded Metal Arc Welding (SMAW) on West tower lift 5 Grillage plate. Joint identified as WSD1-TL5-4B/F-34A, 11B. ZPMC QC Identified as Mao Bin Bin, The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3213-B-U3b.

Repair Welding

This QA Inspector observed ZPMC qualified welding personnel identified as 041271, Perform Shielded Metal Arc

WELDING INSPECTION REPORT

(Continued Page 2 of 4)

Welding (SMAW) on Tower strut. Joint identified as SD1-STSA4-5-119M-1-48A. ZPMC CWI Identified as Yu Dong Ping, with Temporary welding repair report. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-485-SMAW-2G (2F) FCM-Repair-1. For more information see below attach picture number 1.

This QA Inspector observed ZPMC qualified welding personnel identified as 046709, Perform Shielded Metal Arc Welding (SMAW) on Interior splice plate. Joint identified as ESD1-SPSA5-7-3B. ZPMC QC Identified as Xu Jie, The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3211-Tc-U5b-1.

This QA Inspector observed ZPMC qualified welding personnel identified as 046769, Perform Shielded Metal Arc Welding (SMAW) on Interior splice plate. Joint identified as WSD1-SPSA5-2-1B. ZPMC QC Identified as Xu Jie, The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3211-Tc-U5b-1.

This QA Inspector observed ZPMC qualified welding personnel identified as 040611, Perform Shielded Metal Arc Welding (SMAW) on Interior splice plate. Joint identified as ESD1-SPSA5-20-2A. ZPMC QC Identified as Xu Jie, The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3211-Tc-U5b-1.

Ultrasonic Testing:

This QA Inspector observed ZPMC Ultrasonic Testing Inspector, performed UT on Tower Strut web to flange joint. Item identified as ND1-STSA4-6-135M-1, and ED1-STSA4-6-131M-1. For more information see below attach picture number 2 and 3.

Repair Welding: FCAW Process.

This QA Inspector observed ZPMC qualified welding personnel identified as 040759, Perform Flux Core Arc Welding (FCAW) on Grillage Top plate. Joint identified as GTSA5-B/G-6A/B. ZPMC QC Identified as Xu Jie, with Temporary welding repair report. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-345-FCAW-1G (1F)-Repair.

BAY 10: SMAW Process:

This QA Inspector observed ZPMC qualified welding personnel identified as 044511, Perform Shielded Metal Arc Welding (SMAW) on Interior splice plate. Joint identified as NSD1-SPSA5-6-4A, ZPMC QC Identified as Yu Zhi Lai, The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3211-Tc-U5b-1.

This QA Inspector observed ZPMC qualified welding personnel identified as 050266, Perform Shielded Metal Arc Welding (SMAW) on Interior splice plate. Joint identified as SSD1-SPSA5-6-4A, ZPMC QC Identified as Yu Zhi Lai, The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3211-Tc-U5b-1.

This QA Inspector observed ZPMC qualified welding personnel identified as 050289, Perform Shielded Metal Arc Welding (SMAW) on Interior splice plate. Joint identified as NSD1-SPSA5-19-2B, ZPMC QC Identified as Yu

WELDING INSPECTION REPORT


(Continued Page 3 of 4)

Zhi Lai, The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3211-Tc-U5b-1.

Repair Welding

This QA Inspector observed ZPMC qualified welding personnel identified as 057266, 056364, 040280, 040581, Perform Shielded Metal Arc Welding (SMAW) on North, South tower lift 5 Grillage Plate 2 No's, Plate identified as TD5-5. ZPMC QC Identified as Yuan Hai Gang, with Temporary welding repair report WRR-T-WR3372. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-485-SMAW-2G (2F)-Repair-1.

Unless otherwise noted, all work observed on this date appeared to be in general compliance with the applicable contract documents.



Summary of Conversations:

Only general conversation was held between QA and QC concerning this project.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Skyler Guest phone: 15000422360, who represents the Office of Structural Materials for your project.

WELDING INSPECTION REPORT

(Continued Page 4 of 4)

Inspected By:	Gaikwad,Shailesh	Quality Assurance Inspector
----------------------	------------------	-----------------------------

Reviewed By:	Clifford,William	QA Reviewer
---------------------	------------------	-------------
