

**DEPARTMENT OF TRANSPORTATION**

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch  
690 Walnut Ave. St. 150  
Vallejo, CA 94592-1133  
(707) 649-5453  
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: xx.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-019993**Date Inspected:** 04-Nov-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** SHANGHAI CHINA

<b>CWI Name:</b>	Mr. Huang Min		
<b>Inspected CWI report:</b>	Yes	No	N/A
<b>Electrode to specification:</b>	Yes	No	N/A
<b>Qualified Welders:</b>	Yes	No	N/A
<b>Approved Drawings:</b>	Yes	No	N/A

<b>CWI Present:</b>	Yes	No	
<b>Rod Oven in Use:</b>	Yes	No	N/A
<b>Weld Procedures Followed:</b>	Yes	No	N/A
<b>Verified Joint Fit-up:</b>	Yes	No	N/A
<b>Approved WPS:</b>	Yes	No	N/A
<b>Delayed / Cancelled:</b>	Yes	No	N/A

**Bridge No:** 34-0006**Component:** OBG BAY 6 to 8**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance (QA) Inspector Raghavendra Reddy was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island in Shanghai, China. QA observed and/or found the following:

This QA Inspector observed the following work in progress:

**BAY 6**

FCAW welding of welds joint CB3002J-001-253, And Welder is identified as 053609, ZPMC Quality Control (QC) is identified as Mr. Shu Yang Hua. The welding variables appeared to comply with the Applicable WPS-B-T-2234-TC-U4b-F.

FCAW welding of welds joint CB3002K-003-255, And Welder is identified as 0204342, ZPMC Quality Control (QC) is identified as Mr. Shu Yang Hua. The welding variables appeared to comply with the Applicable WPS-B-T-2232-TC-U4b-F.

**BAY 7**

Shielded Metal Arc (SMAW) welding of Weld Joint CB3003F-019-002, And Critical Welding Repair Report(CWR)B-CWR2099, Welder is identified as 054467, ZPMC Quality Control (QC) is identified as Mr. Xu

---

---

# WELDING INSPECTION REPORT

( Continued Page 2 of 2 )

---

---

Hai Yang. The welding variables appeared to comply with the Applicable WPS-345-SMAW-2G(2F)-FCM-Repair.


## BAY 8

FCAW welding of Weld joint BK004A6-055-007, And Welder is identified as 054459, ZPMC Quality Control (QC) is identified as Mr. Liu Fa Wen The welding variables appeared to comply with the Applicable WPS-B-T-2332-TC-P4-F.

FCAW welding of Weld joint BK004A2-055-017, And Welder is identified as 501333, ZPMC Quality Control (QC) is identified as Mr. Liu Fa Wen The welding variables appeared to comply with the Applicable WPS-B-T-2132-plug.

FCAW welding of Weld joint BK004A8-055-002, And Welder is identified as 500405, ZPMC Quality Control (QC) is identified as Mr. Liu Fa Wen The welding variables appeared to comply with the Applicable WPS-B-T-2332-TC-P4-F.

Unless otherwise noted, all work observed on this date appeared to be in general compliance with the applicable contract documents.



### Summary of Conversations:

Only general conversation was held between QA and QC concerning this project.

### Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang (15000422372), who represents the Office of Structural Materials for your project.

---

**Inspected By:** Tharikoppada,Reddy

Quality Assurance Inspector

---

**Reviewed By:** Miller,Mark

QA Reviewer