

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 99.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-025160**Date Inspected:** 14-Nov-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island**Location:** Shanghai**CWI Name:** Tian Lei**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** OBG**Summary of Items Observed:**

On this date Caltrans OSM Quality Assurance (QA) Inspector R. Hernandez was present during the time noted above and conducted observations relative to the work being performed.

The QA Inspector randomly observed the following work in progress:

Bay Number 1

FCAW welding of fillet welds located on Traveler Rails components identified as 20TR2-029 as identified on critical weld repair data sheet B-CWR-1568. Welder is identified as welder no. 069896. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS(s) WPS-345-FCAW-1G(1F)-repair-1.

FCAW welding of fillet welds located on Traveler Rails components identified as 20TR2-030 as identified on critical weld repair data sheet B-CWR-1568. Welder is identified as welder no. 215397. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS(s) WPS-345-FCAW-1G(1F)-repair-1.

Bay Number 2

This QA inspector performed UT of approximately 10% of the area previously tested and accepted by ZPMC Quality Control personnel. This QA Inspector generated an UT report for this date. All components were as listed

WELDING INSPECTION REPORT

(Continued Page 2 of 4)

on NWIT notification no.(s) 07334. The member(s) is/are identified as OBG Floor Beams. The weld designations reviewed are as follows:

1. FB3343-001-165, 047, & 062.
2. FB3343-001-089, 075.
3. FB3343-001-123, 137, 151

FCAW welding of complete joint penetration weld joint(s) located on lift 14 OBG Anchorage Plate component identified as AP3032-001 weld number(s) 335 & 290. Welder is identified as welder no. 045240. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS(s) WPS-B-T-2233-TC-U4b-F.

FCAW welding of complete joint penetration weld joint(s) located on lift 14 OBG Anchorage Plate component identified as AP3032-001 weld number(s) 255 & 903. Welder is identified as welder no. 067942. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS-B-T-2233-TC-U4b-F.

FCAW welding of complete joint penetration weld joint(s) located on lift 14 OBG Anchorage Plate component identified as AP3032-001 weld number(s) 345 & 390. Welder is identified as welder no. 062708. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS-B-T-2233-TC-U4b-F.

FCAW welding of complete joint penetration weld joint(s) located on lift 14 OBG Sub Assembly component identified as West Grillage SA7512-001 weld number(s) 044. Welder is identified as welder no. 066473. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS(s) WPS-B-T-2333-TC-U5-F.

FCAW welding of complete joint penetration weld joint(s) located on lift 14 OBG Sub Assembly component identified as West Grillage SA7512-001 weld number(s) 058. Welder is identified as welder no. 066434. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS(s) WPS-B-T-2233-TC-U5-F.

Bay Number 3

Performed verification VT for the component(s) and corresponding welds for component on OBG Rib Stiffeners components listed as RS3064A-001, RS3064A-002, RS3064A-003, RS3064A-004, RS3064A-005, RS3064C-001, RS3064C-002, RS3064B-001, RS3108A-001, RS3108B-001, & RS3108C-001 for welds identified as welds 001~004. This QA inspector signed green tag #15372.

Performed verification VT for the component(s) and corresponding welds for component on OBG Rib Stiffeners components listed as RS3109A-001, RS3109B-001, RS3109C-001, RS3110A-001, RS3110B-001, RS3110C-001, & RS3110C-002 for welds identified as welds 001~004. This QA inspector signed green tag #15373.

FCAW welding of complete joint penetration weld joint(s) located on lift 14 OBG Longitudinal Diaphragm

WELDING INSPECTION REPORT

(Continued Page 3 of 4)

component identified as LD3041-001 weld number(s) 348. Welder is identified as welder no. 206623. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS(s) WPS-B-T-2232-TC-U4b-F.

FCAW welding of complete joint penetration weld joint(s) located on lift 14 OBG Longitudinal Diaphragm component identified as LD3041-001 weld number(s) 352. Welder is identified as welder no. 055564. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS(s) WPS-B-T-2233-TC-U4b-F.

FCAW welding of complete joint penetration weld joint(s) located on lift 14 OBG Longitudinal Diaphragm component identified as LD3041-001 weld number(s) 039. Welder is identified as welder no. 067036. The welding variables recorded by ZPMC QC identified as Tian Lei appeared to comply with applicable WPS(s) WPS-B-T-2233-TC-U5-F.

Bay 4

This inspector did not observe any welding or contract work in this bay today.

Unless otherwise noted above all items observed on this day appeared to be in general compliance with the applicable contract documents



Summary of Conversations:

Pertinent conversations are included in the body of the report.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang 1500-0042-02372, who represents the Office of Structural Materials for your project.

WELDING INSPECTION REPORT

(Continued Page 4 of 4)

Inspected By: Hernandez,Rene

Quality Assurance Inspector

Reviewed By: Hall,Steven

QA Reviewer