

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 99.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-020545**Date Inspected:** 09-Feb-2011**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC)**Location:** Shanghai, China

CWI Name:	Shao Jian Yuan and Li Yan Hua			CWI Present:	Yes	No	
Inspected CWI report:	Yes	No	N/A	Rod Oven in Use:	Yes	No	N/A
Electrode to specification:	Yes	No	N/A	Weld Procedures Followed:	Yes	No	N/A
Qualified Welders:	Yes	No	N/A	Verified Joint Fit-up:	Yes	No	N/A
Approved Drawings:	Yes	No	N/A	Approved WPS:	Yes	No	N/A
				Delayed / Cancelled:	Yes	No	N/A
Bridge No:	34-0006			Component:	OBG Trial Assembly		

Summary of Items Observed:

On this date Caltrans OSM Quality Assurance (QA) Inspector Mr. S. Manjunath Math was present during the time noted above for observations relative to the work being performed.

This QA Inspector randomly observed the following work in progress:

Orthotropic Box Girder (OBG) at Bay # 14

Segment 14 West

This QA Inspector observed the in-process welding by Shielded Metal Arc Welding (SMAW) process on a Complete Joint Penetration (CJP) groove weld. The Weld joint was designated as DP3174-001-019. The welder identification was 067904 and observed welding in the 2G (Horizontal) position using approved Welding Procedure Specification WPS-B-P-2212-Tc-U4b-FCM-1. The piece mark was identified as the Deck Panel Diaphragm.

Segment 14 West

This QA Inspector observed the in-process welding by Flux Cored Arc Welding (FCAW) process on a Complete Joint Penetration (CJP) groove weld. The Weld joint was designated as DP3167-001-387. The welder identification was 066920 and observed welding in the 3G (Vertical) position using approved Welding Procedure Specification WPS-B-T-2233-ESAB. The piece mark was identified as the weld connecting the Deck Panel

WELDING INSPECTION REPORT

(Continued Page 2 of 4)

Diaphragm to Longitudinal Diaphragm.

Segment 14 East

This QA Inspector observed the in-process welding by Shielded Metal Arc Welding (SMAW) process on a Complete Joint Penetration (CJP) groove weld. The Weld joint was designated as DP3161-001-018. The welder identification was 050969 and observed welding in the 2G (Horizontal) position using approved Welding Procedure Specification WPS-B-P-2212-Tc-U4b-FCM. The piece mark was identified as the weld connecting the Deck Panel Diaphragm to Longitudinal Diaphragm.

Segment 14 West

This QA Inspector observed the in-process welding by Shielded Metal Arc Welding (SMAW) process on a Complete Joint Penetration (CJP) groove weld. The Weld joint was designated as DP3173-001-019. The welder identification was 037779 and observed welding in the 2G(Horizontal) position using approved Welding Procedure Specification WPS-B-P-2212-Tc-U4b-FCM-1. The piece mark was identified as the weld connecting the Deck Panel Diaphragm to Deck Panel.

Please reference the pictures attached for more comprehensive details.

Segment 14 West

This QA Inspector observed the in-process welding by Shielded Metal Arc Welding (SMAW) process on a Complete Joint Penetration (CJP) groove weld. The Weld joint was designated as DP3174-001-018. The welder identification was 037780 and observed welding in the 2G(Horizontal) position using approved Welding Procedure Specification WPS-B-P-2212-Tc-U4b-FCM-1. The piece mark was identified as the weld connecting the Deck Panel Diaphragm to Deck Panel.

Please reference the pictures attached for more comprehensive details.

Segment 14 East

This QA Inspector observed the in-process welding by Flux Cored Arc Welding (FCAW) process on a Complete Joint Penetration (CJP) groove weld. The Weld joint was designated as Seg3019BB-025. The welder identification was 067877 and observed welding in the 3G (Vertical) position using approved Welding Procedure Specification WPS-B-T-2233-ESAB. The piece mark was identified as the weld connecting the Vertical Shear Plate sub assembly identified as SA3358A to Anchorage Plate AP3031A.

Segment 14 East

This QA Inspector observed the in-process welding by Flux Cored Arc Welding (FCAW) process on a Complete Joint Penetration (CJP) groove weld. The Weld joint was designated as Seg3019BB-047. The welder identification was 067877 and observed welding in the 3G (Vertical) position using approved Welding Procedure Specification WPS-B-T-2233-ESAB. The piece mark was identified as the weld connecting the Vertical Shear Plate sub

WELDING INSPECTION REPORT

(Continued Page 3 of 4)

assembly identified as SA3359A to Anchorage Plate AP3031A.

Please reference the pictures attached for more comprehensive details.

Segment 13BW



This QA Inspector observed the in-process welding by Flux Cored Arc Welding (FCAW) process on a Complete Joint Penetration (CJP) groove weld. The Weld joint was designated as Seg3014F-005. The welder identification was 066695 and 201583 and observed welding in the 2G (Horizontal) position using approved Welding Procedure Specification WPS-B-T-2232-ESAB. The piece mark was identified as the weld connecting the Deck Panel Diaphragm to Floor Beam.

Segment 13BE

This QA Inspector observed the in-process welding by Flux Cored Arc Welding (FCAW) process on a Complete Joint Penetration (CJP) groove weld. The Weld joint was designated as Seg3009B-006. The welder identification was 066881 and observed welding in the 2G (Horizontal) position using approved Welding Procedure Specification WPS-B-T-2232-ESAB. The piece mark was identified as the weld connecting the Floor Beam to Deck Panel Diaphragm.


Please reference the pictures attached for more comprehensive details.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.



WELDING INSPECTION REPORT

(Continued Page 4 of 4)



Summary of Conversations:

No relevant conversations were reported on this date.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang 15000422372, who represents the Office of Structural Materials for your project.

Inspected By: Math,Manjunath

Quality Assurance Inspector

Reviewed By: Dsouza,Christopher

QA Reviewer