

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.22P.A**WELDING WITNESS REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WWR-000295**Date Inspected:** 18-Jun-2007**Project Name:** SAS Superstructure**OSM Arrival Time:** 800**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1730**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**Witness:** Procedure Qualification Record
Welding NDT**Welder Qualification**
Mechanical Testing, describe:**Fracture Critical****Index Lot #:** B72-043-07**Witness Lot #:** B26-020-07**Bridge No:** 34-0006**Component:** Bid: 52,55 Tower & Girder**Welder:** Zhang Xing Jin**ID #:** N/A**Joint Description:** B-U2a

N/A

WPS ID #: PWPS-B-T-2233

N/A

Base Metal: A709-50F-2

N/A

PQR ID #: HP2007246-1

N/A

Thickness: 26 millimeters

N/A

Process: FCAW

N/A

Electrode Spec/Class: AWS A5.20/E71T1-1

N/A

Positions: Vertical up (3G)

N/A

Backing Material: A709-50F-2

N/A

CWI: Wei Huang

N/A

Average Amps:

N/A

AWS Code: AWS D1.5 2002

N/A

Average Volts:

N/A

Applicable Sec: Paragraph 5.13

N/A

Travel Speed:

N/A

Heat Input:

N/A

Preheat:

N/A

Summary of Items Observed:

PQR Test Plate HP2007246-1- The Caltrans QA Inspector observed that the presented radiographs appear to be in general compliance with AWS D1.5 (2002). These radiographs have been previously reviewed by ZPMC and ABF representative Mr. Nate Lindell. Additional information relative to the radiographs for this PQR test have been recorded within a Caltrans TL-6031 for this date.

Summary of Conversations:

No conversations relative to the contents of this report.

Observed welding, testing or results:

is in general conformance with the contract requirements.

is not in conformance with the contract requirements.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Mazen Wahbeh, (818) 292-0659, who represents the Office of Structural Materials for your project.

WELDING WITNESS REPORT

(Continued Page 2 of 2)

Inspected By: Cuellar,Robert

Quality Assurance Inspector

Reviewed By: McClary,David

QA Reviewer