



P.O. BOX 23223 Oakland, CA 94623
 Phone (510) 419-0120 / Fax (510) 839-0666

LETTER OF SUBMITTAL
KFM Skyway Project # 04-012024

Run Date 12-Sep-07
 Time 1:47 PM

Dated: 9/12/2007
 To: Doug Coe
 Caltrans-Skyway Project
 345 Burma Road
 Oakland CA 94607
 Phone: Fax:

SUBMITTAL No: KFM-SUB-007505 Rev: 00
 Co/Job # 364-3726
 Contract # 04-012024
 Sub/Supplier: KWI
 Sub/Supplier No:

Subject: Overhead Sign Structures NCR Responses

Special Provis. (SP) REF: 10-1.51
 Standard Spec. (SS) REF: Sect 56-1

RESUBMITTAL/SUPPLEMENTAL REF:

- We are sending the following attached items: Attached Via Fax
- Contract Plans/Specs
 - Drawings/Calculations
 - Change Order
 - Copy of Letter
 - Certs of Compl./Samples
 - Schedule
 - Progress Estimate Request
 - Payroll Information
 - Working Drawings
 - WQCP and/or Addenda
 - Weekly Weld Reports
 - CWR Procedure

| Item | Date | Copies | Description | Drawing No | Rev | Status | Pages |
|------|-----------|--------|--|------------|-----|---------|-------|
| 01 | 12-Sep-07 | 1 | KWO response to NCR #3 (SL11262 reference) | | 0 | Pending | 1 |
| 02 | 12-Sep-07 | 1 | KWO response to NCR #5 (SL11264 reference) | | 0 | Pending | 1 |
| 03 | 12-Sep-07 | 1 | KWO response to NCR #7 (SL11271 reference) | | 0 | Pending | 1 |
| 04 | 12-Sep-07 | 1 | KWO response to NCR #8 (SL11294 reference) | | 0 | Pending | 1 |


- These are transmitted as checked below:
- For Approval
 - For Your Use
 - For Review/Comment
 - As Requested
 - Return For Correction
 - For Information

Remarks:
 Rec'd four letters Friday 9-7-07 from Ricky.

CC:
 Please review / approve by :

Submitted By: Corkey Bates
 (KFM Staff Member - Originator of Transmittal)

Checked & Sent By: [Signature]
 Contract Admin/DCS Staff



Kwan Wo Ironworks Inc.

1383 Armstrong Ave., San Francisco, CA 94124

Phone: (415) 822-9628

Fax: (415) 822-9068

Date: August 24, 2007

Attn: Corkey Bates
KFM
220 Burma Rd.
Oakland, CA

Project: Skyway Bridge
Subject: NCR #3

Corkey:

We are in receipt of NCR #3 issued by State regarding the pentagon sign structures. To resolve the matter, the following steps will be taken by Kwan Wo Ironworks.


1. We will discard the three sign posts and re-fabricate the work.
2. The sign drawings will be re-submitted again with all the missing details incorporated.
3. We will run a qualification procedure and certify our welders for the longitudinal welds and submit for approval.
4. When we start the fabrication, the State will be notified to monitor the work.

Please call if you have any question.

Best regards,

A handwritten signature in black ink, appearing to read "Ricky Ng".

Ricky Ng
Kwan Wo Ironworks, Inc.



Kwan Wo Ironworks Inc.

1383 Armstrong Ave., San Francisco, CA 94124

Phone: (415) 822-9628

Fax: (415) 822-9068

Date: August 24, 2007

Attn: Corkey Bates
KFM
220 Burma Rd.
Oakland, CA

Project: Skyway Bridge
Subject: NCR #5

Corkey:

We are in receipt of NCR #5 issued by State regarding the pentagon sign structures. To resolve the matter, the following steps will be taken by Kwan Wo Ironworks.


1. We will discard the three sign posts and re-fabricate the work.
2. The sign drawings will be re-submitted again with all the missing details incorporated.
3. We will run a qualification procedure and certify our welders for the longitudinal welds and submit for approval.
4. When we start the fabrication, the State will be notified to monitor the work.

Please call if you have any question.

Best regards,

A handwritten signature in black ink, appearing to read "Ricky Ng".

Ricky Ng
Kwan Wo Ironworks, Inc.



Kwan Wo Ironworks Inc.

1383 Armstrong Ave., San Francisco, CA 94124

Phone: (415) 822-9628

Fax: (415) 822-9068

Date: August 24, 2007

Attn: Corkey Bates
KFM
220 Burma Rd.
Oakland, CA

Project: Skyway Bridge
Subject: NCR #7

Corkey:

We are in receipt of NCR #7 issued by State regarding the pentagon sign structures. To resolve the matter, the following steps will be taken by Kwan Wo Ironworks.


1. We will discard the three sign posts and re-fabricate the work.
2. The sign drawings will be re-submitted again with all the missing details incorporated.
3. We will run a qualification procedure and certify our welders for the longitudinal welds and submit for approval.
4. When we start the fabrication, the State will be notified to monitor the work.

Please call if you have any question.

Best regards,

A handwritten signature in black ink, appearing to read "Ricky Ng". The signature is written in a cursive, somewhat stylized font.

Ricky Ng
Kwan Wo Ironworks, Inc.



Kwan Wo Ironworks Inc.

1383 Armstrong Ave., San Francisco, CA 94124

Phone: (415) 822-9628

Fax: (415) 822-9068

Date: September 4, 2007

Attn: Corkey Bates
KFM
220 Burma Rd.
Oakland, CA

Project: Skyway Bridge
Subject: NCR #8

Corkey:

We are in receipt of NCR #8 issued by State regarding the pentagon sign structures. To resolve the matter, the following steps will be taken by Kwan Wo Ironworks.

1. We will discard the three sign posts and re-fabricate the work.
2. The sign drawings will be re-submitted again with all the missing details incorporated.
3. We will run a qualification procedure and certify our welders for the longitudinal welds and submit for approval.
4. When we start the fabrication, the State will be notified to monitor the work.

Please call if you have any question.

Best regards,

A handwritten signature in black ink, appearing to read 'Ricky Ng'.

Ricky Ng
Kwan Wo Ironworks, Inc.

DEPARTMENT OF TRANSPORTATION

SFOBB – Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



*Flex Your Power
Be Energy Efficient!*

November 12, 2007

KFM, a JV
220 Burma Road
Oakland, CA 94607

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-011507

Subject: Resolution to Kwan Wo Ironworks NCR #3, 4, 5, 6, 7 & 8

Dear Mr. Fernando DeLeon,
Attention: Corkey Bates,

The State has reviewed KFM-SUB-007505 regarding the overhead sign structures NCR responses. The State approves Kwan Wo Ironworks the following correctives actions:

1. The three sign structures are to be discarded by Kwan Wo Ironworks.
2. The drawings will be re-submitted with the required details.
3. The applicable Procedure Qualification Record(s) (PQR) and Welding Procedure Specification(s) (WPS) are to be provided and submitted for approval. Welding personnel are to be qualified and certified as applicable and certifications are to be submitted to the Engineer for approval.
4. The Engineer will be notified as required prior to the start of fabrication.

As a result, the subject NCR's are resolved.

If you have any further questions I can be reached at (510) 385-7084.

Sincerely,

<<< ORIGINAL SIGNED >>>

Mr. William Howe
Senior Trans. Engineer

For: Mr. Douglas Coe
Resident Engineer

cc:
file: 5.03.1, 55.7505