



P.O. BOX 23223 Oakland, CA 94623
Phone (510) 419-0120 / Fax (510) 839-0666

LETTER OF SUBMITTAL
KFM Skyway Project # 04-012024

Run Date 05-Jul-05
Time 3:06 PM

Dated: 05-Jul-2005

SUBMITTAL No: KFM-SUB-004777

Rev: 00

To: Doug Coe
Caltrans-Skyway Project
345 Burma Road
Oakland CA 94607
Phone: Fax:

Co/Job # 364-3726
Contract # 04-012024
Sub/Supplier: USI
Sub/Supplier No:

Subject: USI - Documents Clearing NCR #137 (METS NCR #130)

Special Provis. (SP) REF: 10-1.44

Standard Spec. (SS) REF:

RESUBMITTAL/SUPPLEMENTAL REF:

We are sending the following attached items: Attached Via Fax

- Drawing
- Samples
- Payroll
- Change Order
- Plans
- Certificates of Compliance
- Specs
- Schedule
- Prog. Pmt
- Calculations
- Copy of Letter
- Invoice

Item	Date	Copies	Description	Drawing No	Rev	Status	Pages
01	29-Jun-05	1	USI - Documents Clearing NCR #137 (METS NCR #130)		0	Pending	2

These are transmitted as checked below:

- For Approval
- For Your Use
- For Review/comment
- As Requested
- Return For Correction
- For Information

Remarks:

CC:

Please review / approve by : 12-Jul-2005

Submitted By: Rich Bienek
(KFM Staff Member - Originator of Transmittal)

Checked & Sent By:
Contract Admin/DCS Staff



UNIVERSAL STRUCTURAL, INC.

604 S.E. Victory Ave.
Vancouver, WA 98661

P.O. Box 1030
Vancouver, WA 98666

Vancouver (360) 695-1261
Portland (503) 227-2419
FAX (360) 696-3590

June 29, 2005

Kiewit / FCI / Manson, JV (KFM)
220 Burma Road
Oakland, CA 94607
Phone: (510) 419-0120
Fax: (510) 839-0666

Attention: Paul Hegarty / Rich Bienek

Reference: SFOBB Skyway Project
USI #23932 (NCR LTR# 137.062905)

Subject: Response to Caltrans State Letter #5.03.1-007813, DTD 05/18/05
KFM NCR #137

Mr. Hegarty & Mr. Bienek,

Universal Structural, Inc. has received Caltrans State Letter #5.03.1-007813, dated May 18, 2005. Caltrans stated:

"KFM's quality control manager and onsite representatives allowed USI to support the orthotropic box girder (OBG) in a manner inconsistent with the submitted support conditions and supporting calculations. The roller bearing used to maneuver Assembly 4A was placed 380 mm from the free edge where Assembly 4A joins Assembly 3A."

USI agrees that the roller bearings were mistakenly placed in the wrong area. As soon as this discrepancy was pointed out, it was immediately corrected. The personnel involved, along with the foreman were reprimanded and then given proper re-training in the correct placement of these roller bearings.

Please review and submit to Caltrans for a letter to close this NCR. If you have any questions or need further clarification, please contact me at your earliest possible convenience.

Sincerely,
Universal Structural, Inc.

Brad Murphy
Sales Manager

cc: USI file



Category III

A Subsidiary of
HARDER MECHANICAL CONTRACTORS



ELPH
5-20-05

DEPARTMENT OF TRANSPORTATION

SFOBB - Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



Flex Your Power
Be Energy Efficient!

May 18, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

KFM NCR #137

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-007813

Subject: KFM/USI NCR No. 130: Supporting the Orthotropic Box Girder

Dear Mr. Skoro,
Attention: Mr. Rich Bienek,

This Non-Conformance Report (NCR) is issued by the Engineer to KFM as a result of your supplier, USI, for the following reason:

1. KFM's quality control manager and onsite representatives allowed USI to support the orthotropic box girder (OBG) in a manner inconsistent with the submitted support conditions and supporting calculations. The roller bearing used to maneuver Assembly 4A was placed 380 mm from the free edge where Assembly 4A joins Assembly 3A.

This NCR will be tracked as KFM/USI NCR No. 130. KFM/USI was verbally notified of this NCR by Caltrans' METS on 05/17/05. Please review and address how you plan to resolve this NCR and bring your work back into compliance with our contract.

Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

David Wu

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: D. Coe, I. Khinsann, V. Iyer, D. Wu, S. Abbas, B. Chew, H. El-Natur, P. Lowry, I. Kwong, D. Salladay

file: 5.03.1, 9.07.8

DEPARTMENT OF TRANSPORTATION

SFOBB – Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



*Flex Your Power
Be Energy Efficient!*

July 14, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-008278

Subject: Response to KFM-SUB-004644R00, KFM-SUB-004673R00, KFM-SUB-004674R00, KFM-SUB-004675R00, KFM-SUB-004719R00, KFM-SUB-004773R00, KFM-SUB-004774R00, KFM-SUB-004777R00, KFM-SUB-004778R00, KFM-SUB-004780R00, KFM-SUB-004781R00, KFM-SUB-004782R00, KFM-SUB-004783R00

Dear Mr. Skoro,
Attention: Mr. Rich Bienek,

The Engineer takes no exceptions to the following submittals:

- KFM-SUB-004644R00: USI Closing Documents for NCR 126 (METS NCR 113)
- KFM-SUB-004673R00: USI Documents Clearing NCR 147 (METS NCR 140)
- KFM-SUB-004674R00: USI Documents Clearing NCR 148 (METS NCR 141)
- KFM-SUB-004675R00: USI Documents Clearing NCR 149 (METS NCR 143)
- KFM-SUB-004719R00: USI Documents Clearing NCR 89 (METS NCR 74)
- KFM-SUB-004773R00: USI Documents Clearing NCR 153 (METS NCR 142)
- KFM-SUB-004774R00: USI Documents Clearing NCR 154 (METS NCR 144)
- KFM-SUB-004777R00: USI Documents Clearing NCR 137 (METS NCR 130)
- KFM-SUB-004778R00: USI Documents Clearing NCR 155 (METS NCR 145)
- KFM-SUB-004780R00: USI Documents Clearing NCR 158 (METS NCR 148)
- KFM-SUB-004781R00: USI Documents Clearing NCR 159 (METS NCR 150)
- KFM-SUB-004782R00: USI Documents Clearing NCR 160 (METS NCR 151)
- KFM-SUB-004783R00: USI Documents Clearing NCR 166 (METS NCR 156)

Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

<<< ORIGINAL SIGNED >>>

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: P. Lowry, D. Coe, D. Wu, B. Chew, V. Iyer, I. Kwong, D. Salladay
file: 5.03.1, 9.03.8