

P.O. BOX 23223 Oakland, CA 94623
 Phone (510) 419-0120 / Fax (510) 839-0666

LETTER OF SUBMITTAL
KFM Skyway Project # 04-012024

Run Date 03-Jun-05
Time 8:29 AM

Dated: 03-Jun-2005

SUBMITTAL No: KFM-SUB-004588

Rev: 00

To: Doug Coe
 Caltrans-Skyway Project
 345 Burma Road
 Oakland CA 94607
 Phone: Fax:

Co/Job # 364-3726
Contract # 04-012024
Sub/Supplier: USI
Sub/Supplier No:

Subject: USI - Response to KFM NCR 142 (METS NCR 131)

Special Provis. (SP) REF: 08-3.01
Standard Spec. (SS) REF:

RESUBMITTAL/SUPPLEMENTAL REF:

- We are sending the following attached items:**
- Attached
 - Via Fax
 - Drawing
 - Plans
 - Prog. Pmt
 - Samples
 - Certificates of Compliance
 - Calculations
 - Payroll
 - Specs
 - Copy of Letter
 - Change Order
 - Schedule
 - Invoice

Item	Date	Copies	Description	Drawing No	Rev	Status	Pages
01	01-Jun-05	1	USI - Response to KFM NCR 142 (METS NCR 131)		0	Pending	2

These are transmitted as checked below:

- For Approval
- For Review/comment
- Return For Correction
- For Your Use
- As Requested
- For Information


Remarks:

CC:

Please review / approve by : 10-Jun-2005

Submitted By: Rich Bienek
 (KFM Staff Member – Originator of Transmittal)

Checked & Sent By: *SPunk*
 Contract Admin/DCS Staff



UNIVERSAL STRUCTURAL, INC.

604 S.E. Victory Ave.
Vancouver, WA 98661

P.O. Box 1030
Vancouver, WA 98666

Vancouver (360) 695-1261
Portland (503) 227-2419
FAX (360) 696-3590

June 1, 2005

Kiewit / FCI / Manson, JV (KFM)
220 Burma Road
Oakland, CA 94607
Phone: (510) 419-0120
Fax: (510) 839-0666

Attention: Paul Hegarty / Rich Bienek

Reference: SFOBB Skyway Project
USI #23932 (NCR LTR# 142.060105)

Subject: Response to Caltrans State Letter #5.03.1-007845, DTD 05/24/05
KFM NCR #142

Mr. Hegarty & Mr. Bienek,


Universal Structural, Inc. has received Caltrans State Letter #5.03.1-007845, dated May 24, 2005. Caltrans stated:

"KFM's quality control manager and onsite representatives allowed USI to weld a piece of scrap steel to the 100 mm plate of Assembly 2A wing plate pa22. This temporary weld is not shown on the shop drawings."

The incident mentioned was not allowed by KFM's or USI's quality control department; it was a random act by an individual welder that new better and just made a mistake. The individual was severely reprimanded and a letter placed in his file. The said material was removed under the supervision of USI's QCM.

Please review and submit to Caltrans for a letter to close this NCR. If you have any questions or need further clarification, please contact me at your earliest possible convenience.

Sincerely,
Universal Structural, Inc.



Brad Murphy
Sales Manager

cc: USI file



Category III

A Subsidiary of
HARDER MECHANICAL CONTRACTORS



ELPH
5-26-05**DEPARTMENT OF TRANSPORTATION**

SFOBB - Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



Flex Your Power
Be Energy Efficient!

May 24, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-007845

KFM NCR 142

Subject: KFM/USI NCR No. 131: Failure to Show Temporary Welds on Shop Drawings

Dear Mr. Skoro,
Attention: Mr. Rich Bienek,

This Non-Conformance Report (NCR) is issued by the Engineer to KFM as a result of your supplier, USI, for the following reason:

1. KFM's quality control manager and onsite representatives allowed USI to weld a piece of scrap steel to the 100 mm plate of Assembly 2A wing plate pa22. This temporary weld is not shown on the shop drawings.

This NCR will be tracked as KFM/USI NCR No. 131. KFM/USI was verbally notified of this NCR by Caltrans' METS on 05/18/05. Please review and address how you plan to resolve this NCR and bring your work back into compliance with our contract.

Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: D. Coe, I. Khinsann, V. Iyer, D. Wu, S. Abbas, B. Chew, H. El-Natur, P. Lowry, I. Kwong, D. Salladay

file: 5.03.1, 9.06.8

DEPARTMENT OF TRANSPORTATION

SFOBB – Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



*Flex Your Power
Be Energy Efficient!*

June 23, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-008111

Subject: Response to KFM-SUB-004572R00, KFM-SUB-004573R00, KFM-SUB-004571R00, KFM-SUB-004574R00, KFM-SUB-004586R00, KFM-SUB-004587R00, KFM-SUB-004588R00

Dear Mr. Skoro,
Attention: Mr. Rich Bienek,

The Engineer has reviewed the following submittals and takes no exceptions:

- KFM-SUB-004572R00: USI Documents Clearing NCR 135 (METS NCR 127)
- KFM-SUB-004573R00: USI Documents Clearing NCR 136 (METS NCR 129)
- KFM-SUB-004571R00: USI Documents Clearing NCR 134 (METS NCR 121)
- KFM-SUB-004574R00: USI Documents Clearing NCR 109 (METS NCR 94)
- KFM-SUB-004586R00: USI Documents Clearing NCR 146 (METS NCR 135)
- KFM-SUB-004587R00: USI Documents Clearing NCR 145 (METS NCR 134)
- KFM-SUB-004588R00: USI Documents Clearing NCR 142 (METS NCR 131)

Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

<<< ORIGINAL SIGNED >>>

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: D. Coe, I. Khinsann, V. Iyer, D. Wu, S. Abbas, B. Chew, H. El-Natur, P. Lowry, I. Kwong, D. Salladay

file: 5.03.1, 9.06.8