



P.O. BOX 23223 Oakland, CA 94623
 Phone (510) 419-0120 / Fax (510) 839-0666

LETTER OF SUBMITTAL
KFM Skyway Project # 04-012024

Run Date 02-Aug-05
 Time 4:34 PM

Dated: 02-Aug-2005

SUBMITTAL No: KFM-SUB-004965

Rev: 00

To: Doug Coe
 Caltrans-Skyway Project
 345 Burma Road
 Oakland CA 94607
 Phone: Fax:

Co/Job # 364-3726
 Contract # 04-012024
 Sub/Supplier: USI
 Sub/Supplier No: 864

Subject: USI - Documents Clearing KFM NCR #167 (METS #157)

Special Provis. (SP) REF: 08-3.01

Standard Spec. (SS) REF:

RESUBMITTAL/SUPPLEMENTAL REF:

We are sending the following attached items: Attached

Via Fax

- | | | |
|---------------------------------------|---|---|
| <input type="checkbox"/> Drawing | <input checked="" type="checkbox"/> Plans | <input type="checkbox"/> Prog. Pmt |
| <input type="checkbox"/> Samples | <input type="checkbox"/> Certificates of Compliance | <input type="checkbox"/> Calculations |
| <input type="checkbox"/> Payroll | <input type="checkbox"/> Specs | <input type="checkbox"/> Copy of Letter |
| <input type="checkbox"/> Change Order | <input type="checkbox"/> Schedule | <input type="checkbox"/> Invoice |

Item	Date	Copies	Description	Drawing No	Rev	Status	Pages
01	08-Jul-05	1	USI - Documents Clearing KFM NCR #167 (METS #157)		0	Pending	3

These are transmitted as checked below:

- | | | |
|--|---|--|
| <input checked="" type="checkbox"/> For Approval | <input type="checkbox"/> For Review/comment | <input type="checkbox"/> Return For Correction |
| <input type="checkbox"/> For Your Use | <input type="checkbox"/> As Requested | <input type="checkbox"/> For Information |

Remarks:

CC:

Please review / approve by : 09-Aug-2005 _____

Submitted By: Rich Bienek
 (KFM Staff Member – Originator of Transmittal)

Checked & Sent By: *SPurky*
 Contract Admin/DCS Staff



UNIVERSAL STRUCTURAL, INC.

604 S.E. Victory Ave.
Vancouver, WA 98661

P.O. Box 1030
Vancouver, WA 98666

Vancouver (360) 695-1261
Portland (503) 227-2419
FAX (360) 696-3590

July 8, 2005

Kiewit / FCI / Manson, JV (KFM)
220 Burma Road
Oakland, CA 94607
Phone: (510) 419-0120
Fax: (510) 839-0666

Attention: Paul Hegarty / Rich Bienek

Reference: SFOBB Skyway Project
USI #23932 (NCR LTR# 167.070805)

Subject: Response to Caltrans State Letter #5.03.1-008182, DTD 06/29/05
KFM NCR #167

Mr. Hegarty & Mr. Bienek,

Universal Structural, Inc. has received Caltrans State Letter #5.03.1-008182, dated June 26, 2005.


Caltrans stated:

"USI's quality control failed to identify a rejectable ultrasonic (UT) indication located within weld joint 426 of t-stiffener pa64 to web plate pa46 for Assembly 1A."

USI's Quality Control verified this indication and found it to be rejectable. USI's QCM has counseled the UT Technician in proper procedure. The indication has been repaired and found acceptable, please see attached NDE Report.

Please review and submit to Caltrans for a letter to close this NCR. If you have any questions or need further clarification, please contact me at your earliest possible convenience.

Sincerely,
Universal Structural, Inc.


Brad Murphy
Sales Manager

cc: USI file



Category III

A Subsidiary of
HARDER MECHANICAL CONTRACTORS



BL

DEPARTMENT OF TRANSPORTATION

SFOBB - Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



Flex Your Power
Be Energy Efficient!

June 29, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

KFM NCR 167

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-008182

Subject: *USI NCR No. 157: Failure to Identify a Rejectable Indication*

Dear Mr. Skoro,
Attention: Mr. Rich Bienek,

This Non-Conformance Report (NCR) is issued by the Engineer to KFM as a result of your supplier, USI, for the following reason:

- 1. USI's quality control failed to identify a rejectable ultrasonic (UT) indication located within weld joint 426 of t-stiffener pa64 to web plate pa46 for Assembly 1A.

This NCR will be tracked as USI NCR No. 157. USI was verbally notified of this NCR by Caltrans' METS on 06/24/05. Please review and address how you plan to resolve this NCR and bring your work back into compliance with our contract.

Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

David Wu

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: P. Lowry, D. Coe, D. Wu, B. Chew, V. Iyer, I. Kwong, D. Salladay

file: 5.03.1, 9.06.8

DEPARTMENT OF TRANSPORTATION

SFOBB – Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



*Flex Your Power
Be Energy Efficient!*

August 23, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-008541

Subject: Response to KFM-SUB-002138R02, KFM-SUB-004907R00, KFM-SUB-004908R00, KFM-SUB-004909R00, KFM-SUB-004964R00, KFM-SUB-004965R00, KFM-SUB-004966R00

Dear Mr. Zink,
Attention: Mr. Rich Bienek,

The Engineer takes no exceptions to the following submittals:

- KFM-SUB-002138R02: USI Documents Clearing KFM NCR 22 (USI NCR 04-19)
- KFM-SUB-004907R00: USI Documents Clearing KFM NCR 163 (METS 153)
- KFM-SUB-004908R00: USI Documents Clearing KFM NCR 161 (METS 152)
- KFM-SUB-004909R00: USI Documents Clearing KFM NCR 163 (METS 149)
- KFM-SUB-004964R00: USI Documents Clearing KFM NCR 164 (METS 154)
- KFM-SUB-004965R00: USI Documents Clearing KFM NCR 167 (METS 157)
- KFM-SUB-004966R00: USI Documents Clearing KFM NCR 139 (METS 123)

Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

<<< ORIGINAL SIGNED >>>

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: P. Lowry, D. Coe, D. Wu, B. Chew, V. Iyer, I. Kwong, D. Salladay

file: 5.03.1, 9.03.8