



P.O. BOX 23223 Oakland, CA 94623
Phone (510) 419-0120 / Fax (510) 839-0666

LETTER OF SUBMITTAL
KFM Skyway Project # 04-012024

Run Date 22-Nov-05
Time 2:11 PM

Dated: 11/22/05

To: **Doug Coe**
Caltrans-Skyway Project
345 Burma Road
Oakland CA 94607
Phone: Fax:

SUBMITTAL No: KFM-SUB-005752 Rev: 00
Co/Job # 364-3726
Contract # 04-012024
Sub/Supplier: USI
Sub/Supplier No: 1325

Subject: USI - Documents Clearing KFM NCR # 232 (METS #225)

Special Provis. (SP) REF: 08-3.01
Standard Spec. (SS) REF:

RESUBMITTAL/SUPPLEMENTAL REF:

We are sending the following attached items: Attached

Via Fax

- Drawing
- Samples
- Payroll
- Change Order
- Plans
- Certificates of Compliance
- Specs
- Schedule

- Prog. Pmt
- Calculations
- Copy of Letter
- Invoice

Item	Date	Copies	Description	Drawing No	Rev	Status	Pages
01	08-Nov-05	1	USI - Documents Clearing KFM NCR #232 (METS #225)		0	Pending	2

These are transmitted as checked below:

- For Approval
- For Your Use
- For Review/comment
- As Requested
- Return For Correction
- For Information

Remarks:

Please see attached USI Letter and close NCR.

CC:

Please review / approve by : 05-Dec-2005

Submitted By: Rich Bienek

(KFM Staff Member - Originator of Transmittal)

Checked & Sent By: SBurke

Contract Admin/DCS Staff



UNIVERSAL STRUCTURAL, INC.

604 SE. Victory Ave.
Vancouver, WA 98661

P.O. Box 1030
Vancouver, WA 98666

Vancouver (360) 695-1261
Portland (503) 227-2419
FAX (360) 696-3590

November 8, 2005

Kiewit / FCI / Manson, JV (KFM)
220 Burma Road
Oakland, CA 94607
Phone: (510) 419-0120
Fax: (510) 839-0666

Attention: Paul Hegarty / Rich Bienek

Reference: SFOBB Skyway Project
USI #23932 (NCR LTR# 232.110905)

Subject: Response to Caltrans State Letter #5.03.1-009104, DTD 11/04/05
KFM NCR #232

Mr. Hegarty & Mr. Bienek,


Universal Structural, Inc. has received Caltrans State Letter #5.03.1-009104, dated November 04, 2005. Caltrans stated:

"KFM's quality control manager and onsite representatives allowed USI to perform temporary welds on the cover plates of closed ribs on web plate pa345 which are not shown on the working drawings."

The temporary welds in question have been removed and all USI personnel involved in this incident have been dually counseled in the proper procedure. For informational purposes, USI's QC Department has since Mag Particle tested all areas of concern.

Please review and submit to Caltrans for a letter to close this NCR. If you have any questions or need further clarification, please contact me at your earliest possible convenience.

Sincerely,
Universal Structural, Inc.


Brad Murphy
Sales Manager

cc: USI file



Category III

A Subsidiary of
HARDER MECHANICAL CONTRACTORS



DEPARTMENT OF TRANSPORTATION

SFOBB - Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165

COPY



Flex Your Power
Be Energy Efficient!

November 04, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

232

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-009104

Subject: KFM/USI NCR No. 225: Performing Temporary Welds Not Shown on Shop Drawings

Dear Mr. Zink,
Attention: Mr. Rich Bienek,

This Non-Conformance Report (NCR) is issued by the Engineer to KFM as a result of your supplier, USI, for the following reason:

- 1. KFM's quality control manager and onsite representatives allowed USI to perform temporary welds on the cover plates of closed ribs on web plate pa345 which are not shown on the working drawings.

This NCR will be tracked as KFM/USI NCR No. 225. KFM/USI was verbally notified of this NCR by Caltrans' METS on 10/26/05. Please review and address how you plan to resolve this NCR and bring your work back into compliance with our contract.

Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

David Wu

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: P. Lowry, D. Coe, D. Wu, B. Chew, V. Iyer, I. Kwong, D. Salladay

file: 5.03.1, 9.03.8

DEPARTMENT OF TRANSPORTATION

SFOBB – Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



*Flex Your Power
Be Energy Efficient!*

December 05, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-009250

Subject: Response to KFM-SUB-004241R02, KFM-SUB-004871R02, KFM-SUB-005072R02, KFM-SUB-005478R01, KFM-SUB-005464R01, KFM-SUB-005485R01, KFM-SUB-005486R01, KFM-SUB-005489R02, KFM-SUB-005752R00, KFM-SUB-005754R00, KFM-SUB-005755R00

Dear Mr. Zink,
Attention: Mr. Rich Bienek,

The Engineer takes no exceptions to the following submittals:

- KFM-SUB-004241R02: USI Documents Clearing Critical Weld Repair 05-123R1
- KFM-SUB-004871R02: USI Documents Clearing CWR 05-289R3
- KFM-SUB-005072R02: USI Documents Clearing Critical Weld Repair 05-346R2
- KFM-SUB-005478R01: USI Documents Clearing Critical Weld Repair 05-527R2
- KFM-SUB-005464R01: USI Documents Clearing Critical Weld Repair 05-524R1
- KFM-SUB-005485R01: USI Documents Clearing Critical Weld Repair 05-532R2
- KFM-SUB-005486R01: USI Documents Clearing Critical Weld Repair 05-533R2
- KFM-SUB-005489R02: USI Documents Clearing Critical Weld Repair 05-536R1A1
- KFM-SUB-005752R00: USI Documents Clearing KFM NCR 232 (METS 225)
- KFM-SUB-005754R00: USI Documents Clearing KFM NCR 233 (METS 226)
- KFM-SUB-005755R00: USI Documents Clearing KFM NCR 234 (METS 227)

Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

<<< ORIGINAL SIGNED >>>

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: P. Lowry, D. Coe, D. Wu, B. Chew, V. Iyer, I. Kwong, D. Salladay

file: 5.03.1, 9.03.8