



P.O. BOX 23223 Oakland, CA 94623
 Phone (510)4194120/ Fax (510)8394666

LETTER OF SUBMITTAL
 KFM Skyway Project# 04-012024

Run Date 25-Feb-05
 Time 12:14 PM

Dated: 25-Feb-2005

SUBMITTAL No: KFM-SUB-003937

Rev: 00

To: Doug Coe
 Caltrans-Skyway Project
 345 Burma Road
 Oakland CA 94607
 Phone: Fax:

Co/Job # 364-3726
 Contract # 04-012024
 Sub/Supplier: USI
 Sub/Supplier No:

Subject: USI - Documents Clearing USI KFM NCR #84 (METS 69)

Special Provis. (SP) REF: 08-3.01
 Standard Spec. (SS) REF:

RESUBMITTAL/SUPPLEMENTAL REF:

We are sending the following attached items: Attached

Via Fax

- | | | |
|---------------------------------------|---|---|
| <input type="checkbox"/> Drawing | <input type="checkbox"/> Plans | <input type="checkbox"/> Prog. Pmt |
| <input type="checkbox"/> Samples | <input type="checkbox"/> Certificates of Compliance | <input type="checkbox"/> Calculations |
| <input type="checkbox"/> Payroll | <input type="checkbox"/> Specs | <input type="checkbox"/> Copy of Letter |
| <input type="checkbox"/> Change Order | <input type="checkbox"/> Schedule | <input type="checkbox"/> Invoice |

Item	Date	Copies	Description	Drawing No	Rev	Status	Pages
01	23-Feb-05	1	Letter of Transmittal#361		0	Pending	1
02	25-Feb-05	1	USI - Documents Clearing USI KFM NCR #84 (METS 69)		0	Pendina	

These are transmitted as checked below:

- | | | |
|---------------------------------------|---|--|
| <input type="checkbox"/> For Approval | <input type="checkbox"/> For Review/comment | <input type="checkbox"/> Return For Correction |
| <input type="checkbox"/> For Your Use | <input type="checkbox"/> As Requested | <input type="checkbox"/> For Information |

Remarks:

CC:

Please review / approve by : 04-Mar-2005

Submitted By: Rich Bienek
 (KFM Staff Member - Originator of Transmittal)

Checked & Sent By:
 Contract Admin/DCS Staff

Universal Structural, Inc.

a subsidiary of

HARDER MECHANICAL CONTRACTORS, INC.

604 S.E. Victory Avenue, Vancouver, WA. 98661

P.O. Box 1030, Vancouver, WA. 98666

Phone: Vancouver (360) 695-1261 -Portland (503) 227-2419

Fax: (360) 696-3590

LETTER OF TRANSMITTAL

NO: 361

DATE: February 23, 2005

PROJECT: SFOBB Skyway Structure

JOB NO.: 23932

ATTENTION: Paul Hegarty / Rich Bienek

TO: KFM

220 Burma Road
Oakland, CA 94607

WE ARE SENDING YOU

- | | | | |
|---|---------------------------------------|---------------------------------------|---|
| <input type="checkbox"/> Shop Drawings | <input type="checkbox"/> Prints | <input type="checkbox"/> Prints | <input checked="" type="checkbox"/> NCR Responses |
| <input type="checkbox"/> Copy of letter | <input type="checkbox"/> Change order | <input type="checkbox"/> Change order | <input type="checkbox"/> Samples |
| | | | <input type="checkbox"/> Plans |
| | | | <input type="checkbox"/> Specifications |

COPIES	ITEM	DESCRIPTION / REMARKS
1 Original	NCR Response	Caltrans State Letter # 5.03.01-006864, KFM NCR 21R I USI Letter # 21R1.022105
1 Original	NCR Response	(Caltrans State Letter # 5.03.01-006872, KFM NCR 22 USI Letter # 22.022105
1 Original	NCR Response	Caltrans State Letter # 5.03.01-006874, KFM NCR 24 USI Letter # 24.022105
1 Original	NCR Response	Caltrans State Letter # 5.03.01-004895, KFM NCR 48 USI Letter # 48.021505
1 Original	NCR Response	Caltrans State Letter # 5.03.01-006745, KFM NCR 84 USI Letter # 84.022105

SKYWAY BAY BRIDGE PROJECT
KIEWIT / FCI / MANSON, A JV
DATE: 2-25-05
C/O: JBB 364-3726
UTEDBY: NO: 14-012024
TO: RICH BIENEK
SPECIAL NOTES:
INTERNAL KFM COPIES TO:
EXTERNAL COPIES TO:
SCANNED: Y N FILED TO:

THESE ARE TRANSMITTED AS CHECKED BELOW

- For Approval
 For your use
 As Requested
 FOR BIDS DUE

REMARKS: Mr. Hegarty & Mr. Bienek,
Universal Structural, Inc. (USI) is in receipt of the above mentioned Caltrans State Letter's and the following attachments; with individual cover letters is USI's record of subsequent action taken.

Copy To:

Signed:

Brad Murphy

If enclosures are not as noted, kindly notify us at once.



UNIVERSAL STRUCTURAL, INC.

604 S E Victory Ave
Vancouver WA 98661

FO Box1030
Vancouver, WA 98666

Vancouver (360) 695-1261
Portland (503) 227-2419
FAX (360) 696-3590

February 21, 2005

Kiewit/ FCI/ Manson, JV (KFM)
220 Burma Road
Oakland, CA 94607
Phone: (510) 419-0120
Fax: (510) 839-0666

Attention: Paul Hegarty/ Rich Bienek

Reference: SFOBB Skyway Project
USI #23932 (NCR LTR# 84.022105)

Subject: Responseto Caltrans State Letter# 5.03.1-006745, DTD 1/27/05
KFM NCR # 84

Mr. Hegarty & Mr. Bienek,

Universal Structural, Inc. received Caltrans State Letter # 5.03.1-006745, dated January 27, 2005, Caltrans stated that:

"KFM's quality control manager and onsite representatives allowed USI to utilize a temporary support system for Assembly 3A. This was not discussed by KFM, USI, Caltrans and representatives of Smith & Monroe & Gray on 01/11/05 during discussions regarding the moving of Assembly 3A. The Contractor's attention is directed to Section 10-4.44 'Assembly' (revised page #249) of the Special Provisions."

USI agrees that the wrong shims were applied to the Girder Side of the support. As soon as this discrepancy was pointed out, it was immediately corrected. The personnel involved were properly re-trained and USI will take special care in all future type use of temporary support systems.

If you have any questions or need further clarification, please contact me at your earliest possible convenience.

Sincerely,
Universal Structural, Inc.

Brad Murphy
Sales Manager

cc: Brad Young - USI
file



Category III

A Subsidiary of
HARDER MECHANICAL CONTRACTORS



DEPARTMENT OF TRANSPORTATION

SFOBB – Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



*Flex Your Power
Be Energy Efficient!*

January 27, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

KFM NCR 84

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-006745

Subject: KFM/USI NCR No. 69: Use of Temporary Support System

Dear Mr. Skoro,
Attention: Mr. Rich Bienek,

This Non-Conformance Report (NCR) is issued by the Engineer to KFM for the following reason:

1. KFM's quality control manager and onsite representatives allowed USI to utilize a temporary support system for Assembly 3A. This was not discussed by KFM, USI, Caltrans and representatives of Smith & Monroe & Gray on 01/11/05 during discussions regarding the moving of Assembly 3A. The Contractor's attention is directed to Section 10-1.44 'Assembly' (revised page #249) of the Special Provisions.

This NCR will be tracked as KFM/USI NCR No. 69. KFM was verbally notified of this NCR by Caltrans' METS on 01/20/05. Please review and address how you plan to resolve this NCR and bring your work back into compliance with our contract.

Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

<<< ORIGINAL SIGNED >>>

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: D. Coe, I. Khinsann, V. Iyer, D. Wu, S. Abbas, B. Chew, H. El-Natur, P. Lowry, I. Kwong
file: 5.03.1, 9.07.8

DEPARTMENT OF TRANSPORTATION

SFOBB – Skyway Project
345 Burma Road
Oakland, CA 94607
Facsimile Number: (510) 622-5165



*Flex Your Power
Be Energy Efficient!*

March 17, 2005

KFM, a JV
220 Burma Road
Oakland, CA 94607

Contract: 04-012024
04-SF, Ala-80-13.9/14.3, 0.0/1.6
SFOBB Skyway Project
State Letter # 5.03.1-007168

Subject: Response to kfm-sub-002080r08, kfm-sub-002137r03, kfm-sub-002140r02, kfm-sub-002141r02, kfm-sub-003937r00, kfm-sub-003953r00, kfm-sub-003954r00, kfm-sub-003962r00, kfm-sub-003974r00, kfm-sub-003975r00, kfm-sub-003976r00

Dear Mr. Skoro,
Attention: Mr. Rich Bienek,

The Engineer has reviewed the following submittals regarding requests to close non-conformance reports related to the orthotropic box girder:

- kfm-sub-002080r08: USI Documents Clearing KFM NCR 18 (USI No. 04-16) CWR #1 Rev.8
- kfm-sub-002137r03: USI Documents Clearing USI KFM NCR #21 (NCR 04-18)R1
- kfm-sub-002140r02: USI Documents Clearing USI KFM NCR #24 (USI NCR 04-21)R1
- kfm-sub-002141r02: USI Documents Clearing USI KFM NCR #25 (USI NCR 04-22)R1
- kfm-sub-003937r00: USI Documents Clearing USI KFM NCR #84 (METS #69)
- kfm-sub-003953r00: USI Documents Clearing USI KFM NCR #96 (METS #81)
- kfm-sub-003954r00: USI Documents Clearing USI KFM NCR #97 (METS #82)
- kfm-sub-003962r00: USI Documents Clearing USI KFM NCR #88 (METS #73)
- kfm-sub-003974r00: Close Out of USI NCR 81 (METS 66)
- kfm-sub-003975r00: Close Out of USI NCR 82 (METS 67)
- kfm-sub-003976r00: Close Out of USI NCR 83 (METS 68)

The Engineer takes no exceptions to the submittals and agrees the Contractor has sufficiently addressed the subject NCRs. Should you have any questions, please contact David Wu at (510) 622-5104 or Patrick Lowry at (858) 344-2712.

Sincerely,

David Wu
Senior Bridge Engineer

For: Mr. Douglas Coe
Resident Engineer

cc: D. Coe, I. Khinsann, V. Iyer, D. Wu, S. Abbas, B. Chew, H. El-Natur, P. Lowry, I. Kwong

file: 5.03.1, 9.07.8