

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-003785**Date Inspected:** 01-Sep-2008**Project Name:** SAS Superstructure**OSM Arrival Time:** 2200**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 730**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Jiang Jian Fei / Xu Le Feng**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** OBG/Tower**Summary of Items Observed:**

Caltrans Quality Assurance (QA) Inspector Roscoe Dixon arrived on site at the Zhenhua Port Machinery Company (ZPMC) facility at Changxing Island, in Shanghai, China to periodically monitor welding and Quality Control (QC) functions. While on site the QA Inspector observed and or discovered the following.

Heavy Duty Tower Shop 1

The QA Inspector randomly observed four qualified welders identified by ZPMC as welder ID # 067037, 062954, 066912 and 066165 welding longitudinal stiffeners to skin plate (B).

The welding was being performed with an Automatic Carriage machine utilizing the flux cored arc welding (FCAW) process with a 1.4mm diameter electrode, filler metal brand Supercored 71H, class E71T-1.

The Partial Joint Penetration (PJP) weld joints were identified as SSD1-SA18 A/E -9/10, and 13/14. The QA Inspector observed the ZPMC QC CWI Inspector Xu Le Feng verifying welding parameters and pre-heat were in accordance with the Welding Procedure Specification (WPS). The welding parameters observed by QA Inspector Dixon appeared to be in general compliance with the approved WPS-B-T-2332-TC-P5-F.

Heavy Duty Tower Shop 2

The QA Inspector randomly observed two qualified welders identified by ZPMC as welder ID # 068917, 066674 welding lifting lugs to skin plate (C) utilizing the flux cored arc welding (FCAW) process with a 1.4mm diameter

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

electrode, filler metal brand Supercored 71H, class E71T-1.

The QA Inspector observed the ZPMC QC CWI Inspector Jiang Jian Fei verifying welding parameters and pre-heat were in accordance with the Welding Procedure Specification (WPS). The welding parameters observed by QA Inspector Dixon appeared to be in general compliance with the approved WPS-B-T-2332-TC-P5-F.

Summary of Conversations:

As noted within the report shown above.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Ady Velasco, (818) 292-0659, who represents the Office of Structural Materials for your project.

Inspected By:	Dixon,Roscoe	Quality Assurance Inspector
Reviewed By:	Lanz,Joe	QA Reviewer
