

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-004851**Date Inspected:** 30-Nov-2008**Project Name:** SAS Superstructure**OSM Arrival Time:** 1430**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 2230**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China

CWI Name: Wu Ming Kai
Inspected CWI report: Yes No N/A
Electrode to specification: Yes No N/A
Qualified Welders: Yes No N/A
Approved Drawings: Yes No N/A

CWI Present: Yes No
Rod Oven in Use: Yes No N/A
Weld Procedures Followed: Yes No N/A
Verified Joint Fit-up: Yes No N/A
Approved WPS: Yes No N/A
Delayed / Cancelled: Yes No N/A

Bridge No: 34-0006**Component:** OBG**Summary of Items Observed:**

Caltrans Quality Assurance (QA) Inspector, Larry Viars was present to observe fabrication and perform random inspections Orthotropic Box Girder components, for the San Francisco Oakland Bay Self Anchored Suspension Bridge, at Zhenhua Port Machinery Company (ZPMC) facility on Changxing Island.

Sub assembly Bay 4:

The Caltrans QA performed Magnetic Particle Testing (MT) verification and visual inspection of ZPMC tested and accepted SP468A stiffener fillet welds SP432-001-001 through 010, EP69B welds 017 through 020, EP81A welds 001 through 004 and EP81B welds 017 through 020.. After Verification MT and VT verification of stiffener welds Caltrans QA signed ABF documentation for green tagging along with ZPMC and ABF QC. No relevant indications were noted during testing please see MT report TL-6028, generated on this date for further information.

Sub Assembly Bay 3:

The Caltrans QA performed Magnetic Particle Testing (MT) verification and visual inspection of ZPMC tested and accepted OBG I-rib Complete Joint Penetration welds, DP661-001-039, DP653-001-039, DP669-001-041, DP645-001-041, DP643-001-041, DP667-001-041 and DP651-001-025. No relevant indications were noted during testing please see MT report TL-6028, generated on this date for further information.

Summary of Conversations:

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

Only general conversations between Caltrans QA and QC occurred this date.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Peter Dautermann 150 0219 9593, who represents the Office of Structural Materials for your project.

Inspected By:	Viars,Larry	Quality Assurance Inspector
Reviewed By:	Wright,Mark	QA Reviewer
