

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-006429**Date Inspected:** 26-Apr-2009**Project Name:** SAS Superstructure**OSM Arrival Time:** 645**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1845**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Li Yanhua**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** OBG Components**Summary of Items Observed:**

On this date Caltrans OSM Quality Assurance (QA) Inspector, S.Chandrakumar was present during the time noted above for observations relative to the work being performed.

BAY#14

@On going FCAW Welding of Weld Joint 1G-032 Located on SEG028B of 6AE Welder no indentified as 066687,066163 and The welding variables recorded by QC ZMPC to comply with the WPS-B-T-2231-B-U2-F.

@On going SMAW Welding of Weld Joint 3G-002,008 Located on SSD15A-PP37 Welder no indentified as 067611,066478 and The welding variables recorded by QC ZMPC to comply with the WPS-B-T-2213-B-U2.

@On going grinding works for final preparation of Segment 2AW Visual inspection of SSD11A-PP15-85,87 carried out by ZPMC QC Mr. Yin Hai Peng.

Unless otherwise noted, all observed on this date appeared to generally comply with applicable contract documents

Summary of Conversations:

No Relevant Conversation.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

remedial efforts please contact Eric Tsang-150-0042-2372, who represents the Office of Structural Materials for your project.

Inspected By:	Kumar,Chadra	Quality Assurance Inspector
----------------------	--------------	-----------------------------

Reviewed By:	Clifford,William	QA Reviewer
---------------------	------------------	-------------