

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
 690 Walnut Ave. St. 150
 Vallejo, CA 94592-1133
 (707) 649-5453
 (707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-007463**Date Inspected:** 21-Jun-2009**Project Name:** SAS Superstructure**OSM Arrival Time:** 645**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1845**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Li Zhi Jiang**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** OBG Components**Summary of Items Observed:**

On this date Caltrans OSM Quality Assurance (QA) Inspector, Hiranch Patel, was present during the times noted above for observations relative to the work being performed.

Bay#2 Segment 1AAW

This QA inspector performed UT of base metal repair (Pipe hole) area previously tested and accepted by ZPMC Quality Control personnel. The member is identified as segment 1AAW. The location of base metal repair is designated as below:

-(Location A00~A41)

Bay#2 Segment 1AAE

This QA inspector performed UT of base metal repair (Pipe hole) area previously tested and accepted by ZPMC Quality Control personnel. The member is identified as segment 1AAE. The location of base metal repair is designated as below:

-(Location A00~A41)

Bay#2 Segment 1AAW

This QA inspector performed MT after repair of excavation of the area previously tested and accepted by ZPMC Quality Control personnel. This QA Inspector generated an MT report for this date. The member is identified as segment 1AAW. The weld designations reviewed are as follows:

-(Location A33, Shim plate)

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

Bay#2 Segment 1AAW

This QA inspector performed MT after repair of the excavation of the area previously tested and accepted by ZPMC Quality Control personnel. This QA Inspector generated an MT report for this date. The member is identified as segment 1AAW. The weld designations reviewed are as follows:

-(Location A38, Shim plate)

Bay #2, Segment 1AAW

This QA inspector observed the following work in progress:

FCAW welding of weld joint of Shim plate located A00, A01, A02, and A03 on Segment 1AAW. Welder is identified as 048433 (3G). ZPMC QC-CWI is identified as Li Zhi Jiang . The welding variables recorded by QC appeared to comply with the Applicable WPS.

SMAW welding of base metal repair locations A33on Segment 1AAW. Welder is identified as 058242(4G/F). ZPMC QC-CWI is identified as Li Zhi Jiang . The welding variables recorded by QC appeared to comply with the Applicable WPS.

Bay #2, Segment 1AAE

SMAW welding of base metal repair locations A38 and A24 on Segment 1AAE. Welder is identified as 058242(4G/F). ZPMC QC-CWI is identified as Li Zhi Jiang . The welding variables recorded by QC appeared to comply with the Applicable WPS.

Unless otherwise noted, all observed on this date appeared to generally comply with applicable contract documents.

Summary of Conversations:

No relevant conversations.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang 150-0042-2372, who represents the Office of Structural Materials for your project.

| | | |
|----------------------|---------------|-----------------------------|
| Inspected By: | Patel,Hiranch | Quality Assurance Inspector |
| Reviewed By: | Prue,Erik | QA Reviewer |
