

**DEPARTMENT OF TRANSPORTATION**

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch  
690 Walnut Ave. St. 150  
Vallejo, CA 94592-1133  
(707) 649-5453  
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-011968**Date Inspected:** 06-Feb-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Xu Le Feng**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Tower**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance (QA) Inspector Shailesh Gaikwad was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island in Shanghai, China. QA observed and/or found the following:

This QA Inspector observed the following work in progress:

BAY 10

**Repair Welding:**

This QA Inspector observed ZPMC qualified welding personnel identified as 052930, Perform Shielded Metal Arc Welding (SMAW) on Angle Connect Plate. The weld identified as ED1-SA3-18-89M, 99M, 109M, and ND1-SA3-16-89M, 99M, 109M, each three plate. ZPMC QC Identified as Liu Yang, with Critical welding repair report, CWR-T-CWR561. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-485-SMAW-1G (1F)-FCM- Repair-1, WPS-485-SMAW-2G (2F)-FCM- Repair-1, WPS-485-SMAW-3G (3F)-FCM- Repair-1.

**Repair Welding:**

This QA Inspector observed ZPMC qualified welding personnel identified as 057258, Perform Shielded Metal Arc Welding (SMAW) on Bearing Plate. The weld identified as ND1-BPSA5-2-1-4A/B, ZPMC QC Identified as Lilin,

---

---

## WELDING INSPECTION REPORT

( Continued Page 2 of 2 )

---


---

with Critical welding repair report, CWR-T-CWR538. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with, WPS-485-SMAW-2G (2F)-FCM- Repair-1.

### BAY 11:

This QA Inspector observed ZPMC qualified welding personnel identified as 040699. Perform Submerged Arc Welding (SAW) on Tower Flange Plate. Joint identified ED1-STSA4-6-123M-1-3A, ND1-STSA4-6-123M-1-3A, ED1-STSA4-6-127M-1-3A, ED1-STSA4-6-123M-2-3A, ND1-STSA4-6-123M-2-3A, ZPMC CWI Identified as Yu Dong Ping. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-4221-B-U3c-S-1.

Unless otherwise noted, all work observed on this date appeared to be in general compliance with the applicable contract documents.



### Summary of Conversations:

Only general conversation was held between QA and QC concerning this project.

### Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Skyler Guest phone: 15000422360, who represents the Office of Structural Materials for your project.

---

**Inspected By:** Gaikwad,Shailesh

Quality Assurance Inspector

---

**Reviewed By:** Clifford,William

QA Reviewer