

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-012752**Date Inspected:** 14-Mar-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Mr. Yu Dong Ping**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Tower**Summary of Items Observed:**

On this date Caltrans OSM Quality Assurance(QA) Inspector, Baskar Govindarajan, was present during the times noted above for observations relative to the work being performed.

Bay no. 11

1. This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 040155, 041271 perform SMAW welding on, CD corner of West tower, Lift 5, and weld joint identified as WSD1-TL5-4B/F- 2A, 38B. ZPMC CWI Identified as Mr. Xu le feng. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-3211-U4B-1. (Photo attached)

2. This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 040699 perform SAW welding on, Strut flange plate, and weld joint identified as ED1- STSA4-6-131mtr.-2-1B. ZPMC CWI Identified as Mr. Yu Dong Ping. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-4221-B-U3C-S1.

3. This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 042195 perform SAW welding on, Strut angle splice plate, and weld joint identified as SD1- SA4-56-119mtr.-1-1B. ZPMC CWI Identified as Mr. Yu Dong Ping. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-3221-TC-U5-S1

Heavy Dock Jetty

WELDING INSPECTION REPORT

(Continued Page 2 of 3)

4.This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 040704, 040609 perform FCAW welding on, Exterior Bearing stiffener of West tower, Lift 1, Skin B, and weld joint identified as WSD1-SA279-22, 18 and 34. ZPMC CWI Identified as Mr. Ye yong Jun. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-2333-TC-P4-F. (Photo attached)

Visual Inspection Testing:

This QA inspector performed Visual Inspection (VT) of 100% of the area previously tested and accepted by ZPMC Quality Control personnel. The member is identified as Grating support brackets, West tower, Lift 1 , 15 mtr. And 18 mtr. elevation at Tower Erection Jetty. The weld designations reviewed are as follows:

GGSA-1PLAN-W15M- Jt. nos – 1to 6- 25 nos of Brackets

GGSA-1PLAN-W18M- Jt. nos – 1to 6- 32 nos of brackets (Top and bottom)

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.



Summary of Conversations:

No relevant conversations.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Skyler Guest - 15000422360, who represents the Office of Structural Materials for your project.

Inspected By: Baskar, Govindarajan

Quality Assurance Inspector

WELDING INSPECTION REPORT

(Continued Page 3 of 3)

Reviewed By: Clifford, William

QA Reviewer