

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-016684**Date Inspected:** 01-Sep-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Mr. Qiu Wen**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Tower and Orthotropic Box Girder (OBG)**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance (QA) Inspector Shailesh Gaikwad was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island in Shanghai, China. QA observed and/or found the following:

This QA Inspector observed the following work in progress:

BAY 10, SMAW Process:

This QA Inspector observed ZPMC qualified welding personnel identified as 052930, 056200 Perform Shielded Metal Arc Welding (SMAW) on South Tower lift 5 Grillage plate. Joint identified as SSD1-TL5-1B-F-16. ZPMC QC Identified as Li Peng Fei. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3213-Tc-U4c.

This QA Inspector observed ZPMC qualified welding personnel identified as 037743, 066002, Perform Shielded Metal Arc Welding (SMAW) on North Tower lift 5 Grillage plate. Joint identified as NSD1-TL5-3B-F-4, ZPMC QC Identified as Li Peng Fei. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3213-Tc-U4c.

This QA Inspector observed ZPMC qualified welding personnel identified as 037932, 066163, Perform Shielded Metal Arc Welding (SMAW) on North Tower lift 5 Grillage plate. Joint identified as NSD1-TL5-3B-F-10, ZPMC QC Identified as Li Peng Fei. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3213-Tc-U4c.

WELDING INSPECTION REPORT

(Continued Page 2 of 3)

FCAW Process:

This QA Inspector observed ZPMC qualified welding personnel identified as 053870, Perform Flux Core Arc Welding (FCAW) on OBG lift 14 Bottom plate. Joint identified as BP3089-001-001, ZPMC QC Identified as Sun Tian Liang. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-2231-B-U2-f. For more information see below attached picture number 1.

BAY 11

This QA Inspector observed ZPMC qualified welding personnel identified as 070006, 067993, Perform Shielded Metal Arc Welding (SMAW) on West Tower lift 5 Grillage plate. Joint identified as WSD1-TL5-4B-F-5. ZPMC QC Identified as Shao Hai Loang. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3213-Tc-U4c.

This QA Inspector observed ZPMC qualified welding personnel identified as 054460, 040611 Perform Shielded Metal Arc Welding (SMAW) on East Tower lift 5 Grillage plate. Joint identified as ESD1-TL5-2B-F-18, ZPMC QC Identified as Shao Hai Loang. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3213-Tc-U4c.

This QA Inspector observed ZPMC qualified welding personnel identified as 040724, 040723 Perform Shielded Metal Arc Welding (SMAW) on East Tower lift 5 Grillage plate. Joint identified as ESD1-TL5-2B-F-15, ZPMC QC Identified as Shao Hai Loang. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3213-Tc-U4c.

SMAW Process Repair welding:

This QA Inspector observed ZPMC qualified welding personnel identified as 067707 Perform Shielded Metal Arc Welding (SMAW) on West Tower lift 5 Grillage plate. Joint identified as WSD1-TL5-4E-F-20A/B. ZPMC QC Identified as Shao Hai Loang with temporary welding repair report WRR-T-WR3521. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-485-SMAW-3G (3F) Repair.

This QA Inspector observed ZPMC qualified welding personnel identified as 040656, Perform Shielded Metal Arc Welding (SMAW) on Interior splice plate. Joint identified as WSD1-SPSA5-7-2A. ZPMC QC Identified as Wang Chung Xin. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3211-Tc-U5b-1. For more information see below attached picture number 2.

This QA Inspector observed ZPMC qualified welding personnel identified as 040656, Perform Shielded Metal Arc Welding (SMAW) on Interior splice plate. Joint identified as WSD1-SPSA5-7-1A. ZPMC QC Identified as Wang Chung Xin. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3212-Tc-U5b-1.

Unless otherwise noted, all work observed on this date appeared to be in general compliance with the applicable contract documents.

WELDING INSPECTION REPORT

(Continued Page 3 of 3)



Summary of Conversations:

Only general conversation was held between QA and QC concerning this project.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Michael Ng Phone: 15921845703, who represents the Office of Structural Materials for your project.

Inspected By: Gaikwad,Shailesh Quality Assurance Inspector

Reviewed By: Clifford,William QA Reviewer