

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-016908**Date Inspected:** 24-Sep-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Zhu Zhong Hai**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Orthotropic Box Girder (OBG)**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance (QA) Inspector Manoj Prabhune was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island in Shanghai, China. QA observed and/or found the following:

This QA Inspector randomly observed the following work in progress:

OBG # TRIAL ASSEMBLY YARD**Segment # 10CE**

This QA inspector observed, ZPMC qualified welding personnel identified as 047353 perform Flux Core Arc Welding (FCAW), weld joint identified as SEG064B-001; ZPMC QC is identified as Mr. Zhang Xiao Ming. The welding parameters measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-2231-TC-U4b-F. See the attached Photo.

Segment # 10BE ~ 10CE

This QA inspector observed, ZPMC qualified welding personnel identified as 040378 perform Shielded Metal Arc Welding (SMAW), weld joint identified as SP712-001-40; ZPMC QC is identified as Mr. Wang Zhu. The welding parameters measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-P-2214-B-U2-FCM-1.

Segment # 10BE ~ 10CE

WELDING INSPECTION REPORT

(Continued Page 2 of 3)

This QA inspector observed, ZPMC qualified welding personnel identified as 044515 perform Shielded Metal Arc Welding (SMAW), weld joint identified as DP702-001-040; ZPMC QC is identified as Mr. Zhang Xiao Ming The welding parameters measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3213-B-U3b.

Segment # 10BE ~ 10CE

This QA inspector observed, ZPMC qualified welding personnel identified as 057266 perform Shielded Metal Arc Welding (SMAW), weld joint identified as DP715-001-021; ZPMC QC is identified as Mr. Zhong Xiao Ming. The welding parameters measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-3213-B-U3b. See the attached Photo.

Segment # 10BE ~ 10CE

This QA inspector observed, ZPMC qualified welding personnel identified as 040581 perform Shielded Metal Arc Welding (SMAW), weld joint identified as DP702-001-017; ZPMC QC is identified as Mr. Zhong Xiao Ming. The welding parameters measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-4114-1.


Segment # 10CE

This QA inspector observed, ZPMC qualified welding personnel identified as 044504 perform Shielded Metal Arc Welding (SMAW), weld joint identified as SEG064C-011; ZPMC QC is identified as Mr. Zhong Xiao Ming. The welding parameters measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-P-2214-TC-U4b-FCM-1.

Segment # 10CW

This QA inspector observed, ZPMC qualified welding personnel identified as 044551 perform Shielded Metal Arc Welding (SMAW), weld joint identified as SEG063*-036; ZPMC CWI is identified as Mr. Zhu Zhong Hai. The welding parameters measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-P-2212-TC-U4b-FCM-1.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.



WELDING INSPECTION REPORT

(Continued Page 3 of 3)

Summary of Conversations:

Only general conversation was held between QA and QC concerning this project.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang phone: 15000422372, who represents the Office of Structural Materials for your project.

Inspected By:	Prabhune,Manoj	Quality Assurance Inspector
Reviewed By:	Patterson,Rodney	QA Reviewer
