

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-018811**Date Inspected:** 20-Dec-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Zhu Zhong Hai**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Orthotropic Box Girder (OBG)**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance (QA) Inspector Manoj Prabhune was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island in Shanghai, China. QA observed and/or found the following:

This QA Inspector randomly observed the following work in progress:

OBG # TRIAL ASSEMBLY YARD

WELDING:**Segment 12AE ~ 12BE**

This QA Inspector observed ZPMC qualified welding personnel identified as 052763 perform Flux Core Arc Welding (FCAW), weld joint identified as SEG3001X-051; located On Orthotropic Box Girder (OBG) Bottom Plate to Longitudinal Diaphragm CJP Weld; ZPMC Quality Control (QC) is identified as Mr. Liu Hua Jie. The welding variables recorded by QC appeared to comply with applicable WPS-B-T-2232-ESAB.

Segment 12AE ~ 12BE

This QA Inspector observed ZPMC qualified welding personnel identified as 044515 perform Shielded Metal Arc Welding (SMAW), weld joint identified as OBE12D-002; located On Orthotropic Box Girder (OBG) Side Plate to Side Plate Transverse Splice CJP Weld; ZPMC Quality Control (QC) is identified as Mr. Liu Hua Jie. The

WELDING INSPECTION REPORT

(Continued Page 2 of 3)

welding variables recorded by QC appeared to comply with applicable WPS-B-P-2214-B-U2-FCM-1.

Segment 12AE ~ 12BE

This QA Inspector observed ZPMC qualified welding personnel identified as 040320 perform Shielded Metal Arc Welding (SMAW), weld joint identified as OBE12B-001; located On Orthotropic Box Girder (OBG) Bottom Plate to Bottom Plate Transverse Splice CJP Weld; ZPMC Quality Control (QC) is identified as Mr. Liu Hua Jie. The welding variables recorded by QC appeared to comply with applicable WPS-B-P-2214-B-U2-FCM-1. See attached photo for further details.

Segment 12AW ~ 12BW

This QA Inspector observed ZPMC qualified welding personnel identified as 046709 perform Flux Core Arc Welding (FCAW), weld joint identified as OBW12D-002; located On Orthotropic Box Girder (OBG) Side Plate to Side Plate CJP Weld; ZPMC Quality Control (QC) is identified as Mr. Zhu Zhong Hai. The welding variables recorded by QC appeared to comply with applicable WPS-B-P-2214-B-U2-FCM-1. See attached photo for further details.

Segment 12AE

This QA Inspector observed ZPMC qualified welding personnel identified as 040609 perform Flux Core Arc Welding (FCAW), weld joint identified as SEG3004V-051; located On Orthotropic Box Girder (OBG) Bottom Plate to Longitudinal Diaphragm CJP Weld; ZPMC Quality Control (QC) is identified as Mr. Shi Lei. The welding variables recorded by QC appeared to comply with applicable WPS-B-T-2232-ESAB.

Segment 12AW

This QA Inspector observed ZPMC qualified welding personnel identified as 046704 perform Shielded Metal Arc Welding (SMAW), weld joint identified as SEG3005M-090; located On Orthotropic Box Girder (OBG) Bottom Plate to Longitudinal Diaphragm CJP Weld; ZPMC Quality Control (QC) is identified as Mr. Shi Lei. The welding variables recorded by QC appeared to comply with applicable WPS-B-P-2212-TC-U4b-FCM-1.

Unless otherwise noted, all work observed on this date appeared to generally comply with the applicable contract documents.

WELDING INSPECTION REPORT

(Continued Page 3 of 3)



Summary of Conversations:

No significant conversations were reported on this date.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang phone: 15000422372, who represents the Office of Structural Materials for your project.

Inspected By:	Prabhune,Manoj	Quality Assurance Inspector
Reviewed By:	Peterson,Art	QA Reviewer
