

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-019690**Date Inspected:** 21-Jan-2011**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Mr. Xu Le Feng.**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Tower and Orthotropic Box Girder (OBG)**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance (QA) Inspector Shailesh Gaikwad was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island in Shanghai, China. QA observed and/or found the following:

NDT

BAY 10:

This QA Inspector performed randomly Visual Inspection and Magnetic Particle Testing (MT) of approximately 15% of the area previously tested and accepted by ZPMC Quality Control personnel. This QA Inspector generated a TL- 6028 (MT) report for this date. The member is identified as OBG Bike path stringer plate. The weld designations reviewed are as follows.

BK009A4-001-008, 009, 050, 051, 062, 063

BK009A7-001-521, 450, 326, 291, 095, 056, 320, 060, 324, 215, 444, 210

NDT Notification No-08254

This QA Inspector observed the following work in progress:

BAY 10: FCAW Process:

This QA Inspector observed ZPMC qualified welding personnel identified as 040365, Perform Flux Core Arc Welding (FCAW) on OBG Traveler Rail joint. Joint identified as 3005TR3-017, 018, ZPMC QC Identified as

WELDING INSPECTION REPORT

(Continued Page 2 of 3)

Jiang Xiang Bo. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-2132-ESAB. For more information see attached picture number 1.

This QA Inspector observed ZPMC qualified welding personnel identified as 040533, 053869, Perform Flux Core Arc Welding (FCAW) on OBG Bike path railing support plate. Joint identified as BK004A2-031-001, 005, 006, 010. ZPMC QC Identified as Lijun. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-2132-ESAB. For more information see attached picture number 2.

Repair welding, SMAW Process:

This QA Inspector observed ZPMC qualified welding personnel identified as 040582, 050038, 040270, 040581 Perform Shielded Metal Arc Welding (SMAW) on OBG Bike path suspending bracket edge plate. Plate identified as BKX51A weld build up 50mm. ZPMC QC Identified as Li Peng Fei with critical welding repair report CWR-B-CWR1868. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-345-SMAW-2G (2F) Repair.

Repair welding, SMAW Process:

This QA Inspector observed ZPMC qualified welding personnel identified as 057220 Perform Shielded Metal Arc Welding (SMAW) on OBG Bike path suspending bracket edge plate. Plate identified as BKX52A weld build up 50mm. ZPMC QC Identified as Li Peng Fei with critical welding repair report CWR-B-CWR1868. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-345-SMAW-2G (2F) Repair.

Unless otherwise noted, all work observed on this date appeared to be in general compliance with the applicable contract documents.



Summary of Conversations:

Only general conversation was held between QA and QC concerning this project.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Thomas Ho: 150002048250, who represents the Office of Structural Materials for

WELDING INSPECTION REPORT

(Continued Page 3 of 3)

your project.

Inspected By:	Gaikwad,Shailesh	Quality Assurance Inspector
----------------------	------------------	-----------------------------

Reviewed By:	Clifford,William	QA Reviewer
---------------------	------------------	-------------