

**DEPARTMENT OF TRANSPORTATION**

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch  
690 Walnut Ave. St. 150  
Vallejo, CA 94592-1133  
(707) 649-5453  
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: xx.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-019953**Date Inspected:** 31-Oct-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai China**CWI Name:** Mr. Huang Min**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** OBG BAY 5 to 8**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance (QA) Inspector Raghavendra Reddy was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island in Shanghai, China. QA observed and/or found the following:

This QA Inspector observed the following work in progress:

**BAY 6**

Shielded Metal Arc (SMAW) welding of Weld Joint FB3168-002-044, And Welder is identified as 048659, ZPMC Quality Control (QC) is identified as Mr. Zhong Zhi Wei. The welding variables appeared to comply with the Applicable WPS-B-T-2212-B-U2.

Shielded Metal Arc (SMAW) welding of Weld Joint FB3169-002-044, And Welder is identified as 053753, ZPMC Quality Control (QC) is identified as Mr. Zhong Zhi Wei. The welding variables appeared to comply with the Applicable WPS-B-T-2212-B-U2.

**BAY 7**

FCAW welding of welds joint W2-SB10-031-126~131, And Welder is identified as 053742, ZPMC Quality Control (QC) is identified as Mr. Shen Jian Guo. The welding variables appeared to comply with the Applicable

---

---

## WELDING INSPECTION REPORT

( Continued Page 2 of 3 )

---

---

WPS-B-T-2132-3.

FCAW welding of welds joint W2-SB9-054-126~131, And Welder is identified as 217185, ZPMC Quality Control (QC) is identified as Mr. Shen Jian Guo. The welding variables appeared to comply with the Applicable WPS-B-T-2132-3.

FCAW welding of welds joint W2-SB10-030-126~131, And Welder is identified as 215689, ZPMC Quality Control (QC) is identified as Mr. Shen Jian Guo. The welding variables appeared to comply with the Applicable WPS-B-T-2132-3.

BAY 8

FCAW welding of Weld joint BK004A-054-019,020,And Welder is identified as 501333, ZPMC Quality Control (QC) is identified as Mr. Feng Ya Jun The welding variables appeared to comply with the Applicable WPS-B-T-2132-2-Plug.

FCAW welding of welds joint BK004A8-056-090, And Welder is identified as 066421, ZPMC Quality Control (QC) is identified as Mr. Feng Ya Jun. The welding variables appeared to comply with the Applicable WPS-B-T-2332-TC-P4-F-1.

The following Non Destructive Testing (NDT) Inspection carried out as per the ZPMC submitted Notification No. 07182

Magnetic Particle Testing (MT)

This QA Inspector performed MT of approximately 15% of the area previously tested and accepted by ZPMC Quality Control personnel. This QA Inspector generated a MT report for this date. The member is identified as bike path welds. The weld designations reviewed are as follows.

1. BK004A5-055-002,003,004
2. BK004A3-055-002,003,005,007,009,010

Unless otherwise noted, all work observed on this date appeared to be in general compliance with the applicable contract documents.

**Summary of Conversations:**

Only general conversation was held between QA and QC concerning this project.

**Comments**

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Michael Ng (15921845703), who represents the Office of Structural Materials for your project.

---

---

## WELDING INSPECTION REPORT

*( Continued Page 3 of 3 )*

---

---

<b>Inspected By:</b>	Tharikoppada,Reddy	Quality Assurance Inspector
----------------------	--------------------	-----------------------------

<b>Reviewed By:</b>	Miller,Mark	QA Reviewer
---------------------	-------------	-------------