

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-022045**Date Inspected:** 22-Mar-2011**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Mr. Geng Wei.**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Orthotropic Box Girder (OBG)**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance (QA) Inspector Shailesh Gaikwad was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Chang xing Island in Shanghai, China. QA observed and/or found the following:

This QA Inspector observed the following work in progress:

OBG 14EAST

FCAW process:

This QA Inspector observed ZPMC qualified welding personnel identified as 066236 Perform Flux Core Arc Welding (FCAW) on OBG Segment 14 East. Joint identified as SEG3019B-010. ZPMC QC Identified as Xie Ming Feng. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-2233-ESAB.

This QA Inspector observed ZPMC qualified welding personnel identified as 066439 Perform Flux Core Arc Welding (FCAW) on OBG Segment 14 East. Joint identified as SEG3019C-010. ZPMC QC Identified as Xie Ming Feng. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-2233-ESAB.

This QA Inspector observed ZPMC qualified welding personnel identified as 066733 Perform Flux Core Arc Welding (FCAW) on OBG Segment 14 East. Joint identified as SEG3019Z-098, 099, 106, 107. ZPMC QC

WELDING INSPECTION REPORT

(Continued Page 2 of 3)

Identified as Xie Ming Feng. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-T-2231-ESAB.

Repair Welding FCAW Process:

This QA Inspector observed ZPMC qualified welding personnel identified as 066439 Perform Flux Core Arc Welding (FCAW) on OBG Segment 14 East. Joint identified as SEG3019E-2-147. ZPMC QC Identified as Xie Ming Feng with Critical welding repair report CWR-B-CWR2862. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-345-FCAW- 1G (1F)-ESAB- Repair. For more information see attached picture number 1.

SMAW Process:

This QA Inspector observed ZPMC qualified welding personnel identified as 067571 Perform Shielded Metal Arc Welding (SMAW) on OBG Segment 14East. Joint identified as SEG3019AW-039, 040, 048, 049. ZPMC QC Identified as Zhu Yuan Yuan. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-P-2114-FCM-1.

This QA Inspector observed ZPMC qualified welding personnel identified as 068764 Perform Shielded Metal Arc Welding (SMAW) on OBG Segment 14East. Joint identified as SEG3019X-122, 124. ZPMC QC Identified as Zhu Yuan Yuan. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-P-2114-FCM-1.

14 West, SMAW Process:


This QA Inspector observed ZPMC qualified welding personnel identified as 066002 Perform Shielded Metal Arc Welding (SMAW) on OBG Segment Deck panel. Joint identified as DP3168-001-006. ZPMC QC Identified as Shi Lei. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-P-2212-Tc-U4b-FCM. For more information see attached picture number 2.

This QA Inspector observed ZPMC qualified welding personnel identified as 067588 Perform Shielded Metal Arc Welding (SMAW) on OBG Segment Deck panel. Joint identified as SEG3020L-009. ZPMC QC Identified as Shi Lei. The welding parameters as measured using QC's calibrated instrument appeared to be in general compliance with WPS-B-P-2212-Tc-U4b-FCM-1.

Unless otherwise noted, all work observed on this date appeared to be in general compliance with the applicable contract documents.

WELDING INSPECTION REPORT

(Continued Page 3 of 3)



Summary of Conversations:

Only general conversation was held between QA and QC concerning this project.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang: 15000422372, who represents the Office of Structural Materials for your project.

Inspected By: Gaikwad,Shailesh

Quality Assurance Inspector

Reviewed By: Patterson,Rodney

QA Reviewer