

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-022900**Date Inspected:** 22-Apr-2011**Project Name:** SAS Superstructure**OSM Arrival Time:** 1500**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 300**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China

CWI Name: Mr. Li Yang ZPMC
Inspected CWI report: Yes No N/A
Electrode to specification: Yes No N/A
Qualified Welders: Yes No N/A
Approved Drawings: Yes No N/A

CWI Present: Yes No
Rod Oven in Use: Yes No N/A
Weld Procedures Followed: Yes No N/A
Verified Joint Fit-up: Yes No N/A
Approved WPS: Yes No N/A
Delayed / Cancelled: Yes No N/A

Bridge No: 34-0006**Component:** TA Yard OBG 12/13E**Summary of Items Observed:**

On this date Caltrans OSM Quality Assurance (QA) Inspector Robert A. DeArmond was present during the time noted above and conducted observations relative to the work being performed.

TRIAL ASSEMBLY

13AE

Ultrasonic Testing (UT)

This QA inspector performed UT of approximately 10% of the area previously tested and accepted by ZPMC Quality Control personnel. This QA Inspector generated an UT report for this date. All components were as listed on NWIT notification no. 08904. The member(s) is/are identified as Floor Beam Diaphragm to Stiffener Plate. The weld designations reviewed are as follows

DP3078-001-021, 023, 024, 026, 027, 209, 030, 242, 243

DP3076-001-021, 023, 024, 026, 027, 029, 030, 242, 243

TRIAL ASSEMBLY

13AE

This QA Inspector observed the following work in progress:

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

SMAW welding of fillet weld joint(s) located on lift 13AE, SEG3007AA Deck Plate I-Ribs to Edge Plate weld number(s) 005, 019, 012. Welder is identified as welder no. 215553. The welding variables recorded by ZPMC QC identified as Wang Xiang Pin appeared to comply with applicable WPS(s) WPS-B-P-2213-FCM-1.

SMAW welding of fillet weld joint(s) located on lift 13AE, SEG3007AA Deck Plate I-Ribs to Edge Plate weld number(s) 026, 033, 040. Welder is identified as welder no. 216086. The welding variables recorded by ZPMC QC identified as Wang Xiang Pin appeared to comply with applicable WPS(s) WPS-B-P-2213-FCM-1.

SMAW welding of fillet weld joint(s) located on lift 13AE, SEG3009F Bottom Plate I-Ribs to Floor Beam weld number(s) 071, 075, 083. Welder is identified as welder no. 051359. The welding variables recorded by ZPMC QC identified as Wang Xiang Pin appeared to comply with applicable WPS(s) WPS-345-SMAW-3G (3F)-FCM-Repair and B-WR20629.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.

Summary of Conversations:

As mentioned above between QA and QC concerning this project

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Jim Devy 150-002-6784, who represents the Office of Structural Materials for your project.

Inspected By:	DeArmond,Robert	Quality Assurance Inspector
Reviewed By:	Riley,Ken	QA Reviewer
