

**Table 9-8
AVAILABLE CONDUIT AREA
(Square Millimeters)**

	PERCENT OF FILL				
	26%	35%	40%	50%	100%
35	145	194	220	277	555
41	340	460	526	658	1316
53	563	759	867	1084	2168
63	803	1081	1236	1545	3090
78	1237	1666	1904	2380	4761
91	1661	2235	2554	3193	6387
103	2134	2872	3282	4103	8206

As a practical limit, projects for new installations should be designed to the 26% fill limitation.